



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	D18E009A	Project Name:	Hope Christian Elementary School		
NPDES Id. No.	NMR1002NC	Location:	6801 Palomas		
7/7/2021	Owner	Contractor			
Operator	Hope Christian School	PWKI			
Contact name & title	Ieresa Groom	Adam Kenderdine			
e-mail	tkgroom@hcsnm.org	adam@pwki.com			
Contact Phone #	505-821-2513	505-908-5066			
COA Inspector	Thomas Evans	Start/End Time:	8:55 AM-9:05 AM		
Construction Phase:	Stabilization				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	Clear		Temperature: ~	81	
Estimated date of last storm 0.25" or greater	7/6/2021				
Item Number	Deficiency/ Corrective Action				
1	Areas not stabilized on North side. Sediment is washing out on to the concrete pad. Need to stabilize this area per CGP 2.2.14.				
2					
3					
4					
5					
2.1	Discharge off site? (Y/N)	No			
4	Self Inspection Reports	Requested	Latest report Date:	5/12/2021	

Notes:	South side is stabilized.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 07/07/2021