

CITY OF ALBUQUERQUE



February 2, 2018

David Soule, P.E.
Inspections Plus Inc.
805 Nikanda Rd NE
Albuquerque, NM 87107

**Re: Santa Monica Estates Unit 2
Erosion and Sediment Control Plan
Engineer's Stamp Date 1-25-18 (D18E054G)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 1-30-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and to be included in the Work Order construction plans with the condition that following note is applicable:

1. Inspection of erosion and sediment control and other protective measures are required once every 14 days and after a precipitation event of 1/4 inch or greater until the site is considered stabilized by the City. Inspection reports are to be kept by the person or entity authorized to direct construction activities on the site.

Include a copy of the approved plan in the Work Order construction plans.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: e-mail