From: Abiel X. Carrillo
To: Fred Arfman
Subject: Risen Savior Parking Expansion - No Stamp Date - D19D002
Date: Monday, March 21, 2016 10:48:00 AM

Fred,

This email is being sent in lieu of an attached comment letter in order to expedite the response for intermediate reviews. Responses to comments should continue to be included in a re-submittal. A reply to this email with responses to comments will not be considered a re-submittal.

Based upon the information provided in your submittal received 2-3-2016, the above-referenced Grading and Drainage Plan cannot be approved for Building Permit, SO-19 Permit, or Paving Permit until the following item is addressed:

1. Please stamp and date the resubmittal.

2. Add build notes for the curb cut locations along the curbed islands.

3. The sidewalk culvert will need to extend 12" beyond the back of sidewalk.

4. Add Note 8 to the SO-19 notes : "The work in the City ROW must be inspected and accepted. The Contractor must contact Jason Rodriguez at 235-8016 and Construction Coordination at 924-3416 to schedule inspections."

Any question just let me know.

Abiel Carrillo, P.E.

Principal Engineer - Hydrology
Planning Department
Development Review Services Division
City of Albuquerque
505-924-3986
acarrillo@cabq.gov
600 2nd Street NW
Albuquerque, NM 87102