

# CITY OF ALBUQUERQUE



December 28, 2011

Scott M. McGee, P.E.  
9700 Tanoan Dr NE  
Albuquerque, NM 87111

**Re: Albuquerque Memory Care Facility, 8101 Palomas Ave NE, (D19/D028),  
Request for Permanent Certificate of Occupancy - Approved  
Approved Engineer's Stamp date: 1/20/11,  
Certification dated: 12-22-11**

Dear Mr. McGee,

Based upon the information provided in the submittal received 12-23-11, the above referenced Certification is approved for release of Permanent Certificate of Occupancy by Hydrology.

PO Box 1293

The water blocks at the drive entrances were not constructed as designed. Hydrology recommends building a "hump" north of the ADA access paths to function as a water block.

Albuquerque

If you have any questions, you can contact me at 924-3986.

NM 87103

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer—Hydrology  
Development and Building Services

[www.cabq.gov](http://www.cabq.gov)

Copy: e-mail  
CO Clerk—Katrina Sigala