CITY OF ALBUQUERQUE



June 10, 2020

Roger Cinelli, RA Roger Cinelli and Associates Inc. Architects 2418 Manuel Torres Ln NW Albuquerque, NM 87107

Re: Dorado Montano Townhouses 5915 Golden NW

Traffic Circulation Layout

Architect's Stamp 06-01-20 (E10-D079)

Dear Mr. Cinelli,

Based upon the information provided in your submittal received 06-09-20, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

- Please coordinate all calculations for parking spaces, including bicycle and motor cycle parking with Zoning and list the number required. Please verify.
- 2. The minimum parking stall dimensions are:

Type of parking	Min. Width	Min. Length	Min. Overhang
Standard	8.5'	18'	2'
Compact	7.5'	15'	1.5'
Motorcycle	4'	8'	N/A
ADA	8.5'	18'	2'

NM 87103

Albuquerque

PO Box 1293

www.cabq.gov

Will this be a problem if you overhang is 2 ft and your proposed 6 ft.ADA pedestrian pathway You see, 2 ft overhang will reduce the proposed 6 ft pathway to 4 ft. This will be a problem. Please clarify.

- The 6 ft. wide ADA accessible pedestrian pathway from the public sidewalk to the building entrances will need to be unstripped thru proposed Fire and Refuse drive aisle.
- 4. ADA parking stall signage panel, for the 5 ft access aisle, is facing the wrong direction. But, Per DPM, a 6 ft. wide ADA accessible pedestrian pathway is required from the ADA parking stall access aisles to the building entrances not 5ft. Please clearly show this pathway and provide details.
- 5. The proposed curbing around proposed landscape and parking with need to encompass the perimeter of the landscaping on all proposed landscaping islands.

- 6. Parking areas shall have barriers to prevent vehicles from extending over proposed 6ft wide ADA pedestrian pathway/sidewalk.
- 7. Provide a copy of refuse approval for design and location of proposed refuse container.
- 8. Please provide a intersection sight distance exhibit (See attached exhibit):
 - For Golden Ave and the proposed 3 ft block wall on Montano Road
 - For drive aisle and proposed 3ft block wall on Golden Ave
- 9. Show the clear sight triangle and add the following note to the plan: "Landscaping and signage will not interfere with clear sight requirements. Therefore, signs, walls, trees, and shrubbery between 3 and 8 feet tall (as measured from the gutter pan) will not be acceptable in the clear sight triangle.
- 10. Keyed Note 17: References 3/Civil 101 but you already provided a detail on the proposed TCL sheet. Please clear this issue.
- 11. Provide Keyed Note 2.
- 12. Provide existing sidewalk width along Golden Ave.
- 13. Keyed Note 3: How will you provide 3ft ADA pathway across proposed driveway? Provide detail showing ADA pathway.
- 14. Keyed Note 7: Please show how you will provide a clear pathway around proposed fire hydrant. Look at COA STD DWG 2431.
- 15. Please specify the City Standard Drawing Number when applicable.

Notes 16, 17 & 18: if applicable for any water/sanitary/sewer on public streets

- 16. Provide notes showing what work is included and on the work order and the private work on site.
- 17. Work within the public right of way requires a work order with DRC approved plans.
- 18. Please add a note on the plan stating "All improvements located in the Right of Way must be included on the work order."
- 19. Unused curb cuts must be replaced with sidewalk and curb & gutter. A build note must be provided referring to the appropriate City Standard drawing (If applicable on Montano Road).

Once corrections are complete resubmit

- 1. The Traffic Circulation Layout
- 2. A Drainage Transportation Information Sheet (DTIS)
- 3. Send an electronic copy of your submittal to PLNDRS@cabq.gov.
- 4. The \$75 re-submittal fee.

for log in and evaluation by Transportation.

If you have any questions, please contact me at (505) 924-3630.

Sincerely

Nilo Salgado-Fernandez, P.E. Senior Engineer, Planning Dept. Development Review Services

C: CO Clerk, File

CITY OF ALBUQUERQUE



PO Box 1293

Albuquerque

NM 87103

www.cabq.gov