# CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

August 23, 2022

David Soule, P.E. **Rio Grande Engineering** PO Box 93924 Albuquerque, New Mexico 87199

RE: Lot 7 Block 3 Volcano Cliffs Unit 2 SAD 227 5619 Kimberlite Dr. NW **Grading and Drainage Plan Engineers Stamp Date 7/13/2022 (E10D119)** Pad Certification Date 8/18/2022

Mr. Soule,

Albuquerque

NM 87103

PO Box 1293 Based upon the information provided in your submittal received 8/22/2022, this plan is approved

for building permit.

Please inform the builder/owner to attach a copy of this approved plan and this letter to the

construction sets in the permitting process prior to sign-off by Hydrology.

Reiterate to the Owner/Contractor that a separate permit for a garden/retaining wall must be obtained, with the approved G&D plan and Pad Certification. Advise the owner &

Contractor that dirt is not allowed in the public right of way to climb the curb. Crusher

fines or lumber is allowed. If dirt is used this will delay going forward with the construction

of the home.

www.cabq.gov Prior to Certificate of Occupancy release, Engineer Certification per the DPM checklist of this

plan will be required.

If you have any questions, please contact me at 924-3999 or Rudy Rael at 924-3977.

Sincerely,

Shahab Biazar, P.E.

City Engineer, Hydrology

**Building & Development Services** 

RR/SB

# CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

File E10D119

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



# City of Albuquerque

### Planning Department

### Development & Building Services Division

## DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

Project Title:	OR NW Building Permit	t #: Hvdro	ology File #:					
DRB#:	EPC#:	Work	Order#:					
DRB#: Legal Description: LOT 7 , BL	OCK 3 VOLCANO	CLIFFS UNIT 2						
City Address: 5619kimberlite	DR NW							
Applicant:		Contac	t:					
Address:								
Phone#:								
Other Contact: RIO GRANDE EN								
Address: PO BOX 93924 ALE		Contact						
Phone#: 505.321.9099	***************************************	.0999 E-mail:	david@riograndeengineering.com					
TYPE OF DEVELOPMENT:								
Check all that Apply:		DRD SITE _	_ ADMIN SITE					
<b>DEPARTMENT:</b> _X HYDROLOGY/ DRAINAGE		TYPE OF APPROVAL/ACC	EPTANCE SOUGHT:					
TRAFFIC/ TRANSPORTATION		_X_BUILDING PERMIT APPROVAL						
		CERTIFICATE OF OCCU	UPANCY					
TYPE OF SUBMITTAL:								
ENGINEER/ARCHITECT CERTIFIC	CATION	PRELIMINARY PLAT A						
× PAD CERTIFICATION		SITE PLAN FOR SUB'D						
CONCEPTUAL G & D PLAN		SITE PLAN FOR BLDG.						
GRADING PLAN		FINAL PLAT APPROVA	AL					
DRAINAGE REPORT								
DRAINAGE MASTER PLAN		SIA/ RELEASE OF FINA	NCIAL GUARANTEE					
FLOODPLAIN DEVELOPMENT PE	RMIT APPLIC	FOUNDATION PERMIT APPROVAL						
ELEVATION CERTIFICATE		GRADING PERMIT APPROVAL						
CLOMR/LOMR		SO-19 APPROVAL						
TRAFFIC CIRCULATION LAYOUT	(TCL)	PAVING PERMIT APPROVAL						
TRAFFIC IMPACT STUDY (TIS)		GRADING/ PAD CERTIFICATION						
STREET LIGHT LAYOUT		WORK ORDER APPROVA	AL					
OTHER (SPECIFY)		CLOMR/LOMR						
PRE-DESIGN MEETING?		FLOODPLAIN DEVELOPMENT PERMIT						
IS THIS A RESUBMITTAL?: _X_Yes	No	OTHER (SPECIFY)						
DATE SUBMITTED:								
COA STAFF:		BMITTAL RECEIVED:						
	FEE PAID:							
	1 PP 1 A1D,							

### Weighted E Method

												100-Yea	r, 6-hr.	24 hour
Basin	Area	Area	Treat	ment A	Treat	ment B	Treat	ment C	Treati	ment D	Weighted E	Volume	Flow	Volume
	(sf)	(acres)	%	(acres)	%	(acres)	%	(acres)	%	(acres)	(ac-ft)	(ac-ft)	cfs	(ac-ft)
ALLOWED	12600.00	0.289	0%	0	20%	0.058		0.1331		0.098	1.259	0.030	0.93	0.034
FRONT	12600.00	0.289	0%	0	20%	0.058	36%	0.1041	44%	0.127	1.357	0.033	0.97	0.038

### **Equations:**

Weighted E = Ea\*Aa + Eb\*Ab + Ec\*Ac + Ed\*Ad / (Total Area)

Volume = Weighted D \* Total Area

Flow = Qa \* Aa + Qb \* Ab + Qc \* Ac + Qd \* Ad

Where for 100-year, 6-hour storm-zone 1

Eb= 0.67 Qb= 2.03 Qc= 2.87 Ec= 0.99 Ed= 1.97 Qd= 4.37


ONSITE Conditions DRAINAGE SUMMARY


REQUIRED PROVIDED FLOOD CONTROL ` 870

### Narrative

This site is within the SAD 227 Master Drainage plan boundaries. The site is to maintain existing patterns and drain to the adjacent open space property to the east per the master drainage plan. The site does exceed the SAD 227 developed conditions assumptions, therefore ponding is required. Due to the site being within the height restriction area, ponds and drainage pipes are proposed to minimize elevation of the building drain to the street and the rear yard fills aand overflows to the openspace. Upland flow does not impact the property.

> CONSTRUCT ALL SWALES AND EROSION PROTECTION (SHOWN HATCHED) BELOW ADJACENT GRADE TO ENDSURE






I, DAVID SOULE HAVE PERSONALLY INPECTED THE SITE. I HEREBY CERTIFY THE PAD HAS BEEN CONSTRUCTED SUCH THAT IT IS IN SUBSTANTIAL CONFORMANCE TO THE APPROVED GRADING PLAN DATED 7/13/22




# **EROSION CONTROL NOTES:**

- 1. CONTRACTOR IS RESPONSIBLE FOR OBTAINING A TOPSOIL DISTURBANCE PERMIT PRIOR TO BEGINNING WORK.
- 2. CONTRACTOR IS RESPONSIBLE FOR MAINTAINING RUN-OFF ON SITE DURING CONSTRUCTION.
- 3. CONTRACTOR IS RESPONSIBLE FOR CLEANING ALL SEDIMENT THAT GETS INTO EXISTING RIGHT-OF-WAY.
- 4. REPAIR OF DAMAGED FACILITIES AND CLEANUP OF SEDIMENT ACCUMULATIONS ON ADJACENT PROPERTIES AND IN PUBLIC FACILITIES IS THE RESPONSIBILITY OF THE CONTRACTOR.
- 5. ALL EXPOSED EARTH SURFACES MUST BE PROTECTED FROM WIND AND WATER EROSION PRIOR TO FINAL ACCEPTANCE OF ANY PROJECT.



Effective LOMRs





# **LEGAL DESCRIPTION:**

LOT 7 BLOCK 3 UNIT 2 VOLCANO CLIFFS
CITY OF ALBUQUERQUE, BERNAILILLO COUNTY, NEW MEXICO

## NOTES:

- 1. ALL SPOT ELEVATIONS REPRESENT FLOWLINE ELEVATION UNLESS OTHERWISE NOTED.
- 2. ALL SLOPES SHALL BE 3:1 MAX. AND GRAVEL OR NATIVE SEEDING PRIOR TO CO.
- 3. ANY PERIMETER WALLS MUST BE PERMITED SEPARATELY ALL RETAINING WALL DESIGN SHALL BE BY OTHERS.
- DATUM 1988. 5. A PAD ELEVATION CERTIFICATION SHALL BE REQUIRED PRIOR TO RELEASE OF BUILDING


4. SURVEY INFORMATION PROVIDED BY COMMUNITY SCIENCES CORPORATION USING NAVD


LEGEND	
XXXX	EXISTING CONTOUR
XXXX	EXISTING INDEX CONTOUR
XXXX <del>-</del>	PROPOSED CONTOUR
	PROPOSED INDEX CONTOUR
× XXXX	EXISTING SPOT ELEVATION
● XXXX	PROPOSED SPOT ELEVATION
	BOUNDARY
	ADJACENT BOUNDARY
=========	EXISTING CURB AND GUTTE
<del></del>	PROPOSED EARTHEN SWAL
	PROPOSED CONCRETE

# HIGHEST NATURAL/ RETENTION POND GARDE= 5332.07 TOP=5330.77 BOTTOM=5329.90 **SWALE** VOLUME=444 CF 2-4" PVC DRAINS LOWEST NATURAL INV=5329.90 Project Benchmark GARDE= 5330.27 Set Mag Nail w/Flagging 5330.58 Elev=5330.84 ¥5330.85 FF= 5332.67 FP= 5332.17 AVERAGE NATURAL GRADE= 5331.17 **5619 Kin** 60' 5' P.U.E. TURN BLOĆK EARTHEN @ 30.95 RETENTION POND **SWALE** TOP=5331.00 Lot 8 OVERFLOW=5330.85 BOTTOM=5329.75 VOLUME=426 CF

5330.49 🐰

**CAUTION:** EXISTING UTILITIES ARE NOT SHOWN. IT SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR TO CONDUCT ALL NECESSARY FIELD INVESTIGATIONS PRIOR TO ANY EXCAVATION TO DETERMINE THE ACTUAL LOCATION OF UTILITIES & OTHER IMPROVEMENTS.





P.E. #14522

# 5619 Kimberlite Drive NW GRADING AND DRAINAGE PLAN

PROPOSED PONDING

Rio Grande PO BOX 93924 ALBUQUERQUE, NM 87199 (505) 321-9099

SHEET# C1 Lingineering JOB#

DRAWN

 $^{BY}$  DEM

DATE 7-11-22

C:\Danny\RGS-DAVID SOULE\STD-G&D.dwg

# 7/13/22 DAVID SOULE