
CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



July 2, 2025

David Soule, P.E. Rio Grande Engineering PO BOX 93924 Albuquerque, NM 87199

RE: 8004 Shiprock Ct NW

Grading & Drainage Plan Engineer's Stamp Date: 6/30/25

Hydrology File: E10D129 Case # HYDR-2025-00229

Dear Mr. Soule:

PO Box 1293

Based upon the information provided in your submittal received 6/30/2025, the Grading & Drainage Plan **is not approved** for Building Permit. The following comments need to be addressed for approval of the above referenced project.

Albuquerque

 $1. \ \ \, \text{Please provide the FIRM Map} \, \underline{\text{and floodplain note}} \, \text{with effective date}.$

NM 87103

www.cabq.gov

The FF is lower than the FP. Please correct.

SHIPROCK CT. N.W

WATER QUALOUTY POND
TOP = 22.25

BOTTOM: 20.50

VOLUME: 42.07

22.50

AVG. NATIVE GRADE: 5322.00

PP: 5322.00

AVG. NATIVE GRADE: 5321.63

REAR YARD
RETENTION PONE
TOP: 21.55

BOTTOM: 20.75
VOLUME: 1,156 CI

CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

As a reminder, if the project total area of disturbance (including the staging area and any work within the adjacent Right-of-Way) is 1 acre or more, then an Erosion and Sediment Control (ESC) Plan and Owner's certified Notice of Intent (NOI) is required to be submitted to the Stormwater Quality Engineer (Doug Hughes, PE, jhughes@cabq.gov, 505-924-3420) 14 days prior to any earth disturbance.

If you have any questions, please contact me at 505-924-3314 or amontoya@cabq.gov.

Sincerely,

Anthony Montoya, Jr., P.E., CFM

Senior Engineer, Hydrology

anth Mars

Planning Department, Development Review Services

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov