

CITY OF ALBUQUERQUE



December 13, 2017

David Soule, P.E.
Inspections Plus Inc.
4382 Alexander Blvd NE
Albuquerque, NM 87107

**Re: Legacy Home Healthcare
Erosion and Sediment Control Plan
Engineer's Stamp Date 12-12-17 (E12E006F)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 12-13-17, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the following conditions:

1. A sediment BMP (silt fence or filter sock) is required at the downstream end of the riprap rundowns. A sediment BMP is required along the entire eastern edge of the site.
2. Use the legend from the plan with stamp date 12-5-17, as it got shifted in the latest revision.

Include a copy of the approved plan in the Building Permit set.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email