

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Interim Director



Mayor Timothy M. Keller

April 11, 2022

David Soule, P.E.
Rio Grande Engineering
PO Box 93924
Albuquerque, NM 87199

**RE: 5501 La Colonia Drive NW
5501 La Colonia Drive NW
Engineer's Stamp Date: 4/8/22
Hydrology File: E12D042**

Dear Mr. Soule:

Based upon the information provided in your submittal received 4/11/22, the Grading & Drainage Plan is approved for Grading Permit (earthwork can get started for the earth pad on the house).

Once the grading is complete, a pad certification (meaning that the earthwork is complete) will be required prior to release from Hydrology during the Building Permit process. Also, at the time of pad certification approval, Hydrology will concurrently approve the Grading & Drainage Plan for Building Permit.

As a reminder, if the project total area of disturbance (including the staging area and any work within the adjacent Right-of-Way) is 1 acre or more, then an Erosion and Sediment Control (ESC) Plan and Owner's certified Notice of Intent (NOI) is required to be submitted to the Stormwater Quality Engineer (Dough Hughes, PE, jhughes@cabq.gov, 924-3420) 14 days prior

If you have any questions, please contact me at 924-3695 or dggutierrez@cabq.gov

Sincerely,

David G. Gutierrez, P.E.
Senior Engineer, Hydrology
Planning Department



City of Albuquerque

Planning Department
Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

Project Title: 5501 La Colonia DR NW **Building Permit #:** _____ **Hydrology File #:** _____
DRB#: _____ **EPC#:** _____ **Work Order#:** _____
Legal Description: TRACT A ESTATES AT TAYLOR RIDGE
City Address: 5501 La Colonia DR NW

Applicant: _____ **Contact:** _____
Address: _____
Phone#: _____ **Fax#:** _____ **E-mail:** _____

Other Contact: RIO GRANDE ENGINEERING **Contact:** DAVID SOULE
Address: PO BOX 93924 ALB NM 87199
Phone#: 505.321.9099 **Fax#:** 505.872.0999 **E-mail:** david@riograndeengineering.com

TYPE OF DEVELOPMENT: _____ PLAT ☒ RESIDENCE _____ DRB SITE _____ ADMIN SITE

Check all that Apply:

DEPARTMENT:
☒ HYDROLOGY/ DRAINAGE
_____ TRAFFIC/ TRANSPORTATION

TYPE OF SUBMITTAL:
_____ ENGINEER/ARCHITECT CERTIFICATION
_____ PAD CERTIFICATION
_____ CONCEPTUAL G & D PLAN
☒ GRADING PLAN
_____ DRAINAGE REPORT
_____ DRAINAGE MASTER PLAN
_____ FLOODPLAIN DEVELOPMENT PERMIT APPLIC
_____ ELEVATION CERTIFICATE
_____ CLOMR/LOMR
_____ TRAFFIC CIRCULATION LAYOUT (TCL)
_____ TRAFFIC IMPACT STUDY (TIS)
_____ STREET LIGHT LAYOUT
_____ OTHER (SPECIFY) _____
_____ PRE-DESIGN MEETING?

IS THIS A RESUBMITTAL?: ☒ Yes _____ No

TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

☒ BUILDING PERMIT APPROVAL
_____ CERTIFICATE OF OCCUPANCY
_____ PRELIMINARY PLAT APPROVAL
_____ SITE PLAN FOR SUB'D APPROVAL
_____ SITE PLAN FOR BLDG. PERMIT APPROVAL
_____ FINAL PLAT APPROVAL
_____ SIA/ RELEASE OF FINANCIAL GUARANTEE
_____ FOUNDATION PERMIT APPROVAL
_____ GRADING PERMIT APPROVAL
_____ SO-19 APPROVAL
_____ PAVING PERMIT APPROVAL
_____ GRADING/ PAD CERTIFICATION
_____ WORK ORDER APPROVAL
_____ CLOMR/LOMR
_____ FLOODPLAIN DEVELOPMENT PERMIT
_____ OTHER (SPECIFY) _____

DATE SUBMITTED: _____ **By:** _____

COA STAFF:

ELECTRONIC SUBMITTAL RECEIVED: _____

FEE PAID: _____

Weighted E Method

Basin	Area		Treatment A		Treatment B		Treatment C		Treatment D		Weighted Volume (ac-ft)	Flow cfs
	(sf)	(acres)	% (acres)	% (acres)	% (acres)	% (acres)	% (acres)	% (acres)	% (acres)	% (acres)		
Historical	8713.00	0.200	85%	0.17	15%	0.030	0%	0%	0%	0.000	0.475	0.008
PROPOSED	8713.00	0.200	0%	0	20%	0.040	38%	0.076	42%	0.084	1.338	0.022
COMPARISON											0.014	0.39

Equations:

Weighted E = Ea**A*a + Eb**A*b + Ec**A*c + Ed**A*d / (Total Area)

Volume = Weighted D * Total Area

Flow = Qa * *A*a + Qb * *A*b + Qc * *A*c + Qd * *A*d

Where for 100-year, 6-hour storm- zone 1

Ea= 0.44	Qa= 1.29
Eb= 0.67	Qb= 2.03
Ec= 0.99	Qc= 2.87
Ed= 1.97	Qd= 4.37

ONSITE Conditions



100-YEAR 6 HOUR VOLUMES

GENERATED (CF)	RETAINED (CF)
627	218

This site is within a fully developed area within the Taylor Ridge subdivision E12/D8 in NW Albuquerque. All of the adjacent sites free discharge to the street. The drainage report is not available, the plan appears to call for free discharge. The site is not impacted by upland flows. The site will retain 213 cf and discharge to the roadway in conformance to the master drainage plan. The site is not required to retain the water quality volume. existing patterns and drain to the historical outfall west of the site.

EROSION CONTROL NOTES:

- CONTRACTOR IS RESPONSIBLE FOR OBTAINING A TOPSOIL DISTURBANCE PERMIT PRIOR TO BEGINNING WORK.
- CONTRACTOR IS RESPONSIBLE FOR MAINTAINING RUN-OFF ON SITE DURING CONSTRUCTION.
- CONTRACTOR IS RESPONSIBLE FOR CLEANING ALL SEDIMENT THAT GETS INTO EXISTING RIGHT-OF-WAY.
- REPAIR OF DAMAGED FACILITIES AND CLEANUP OF SEDIMENT ACCUMULATIONS ON ADJACENT PROPERTIES AND IN PUBLIC FACILITIES IS THE RESPONSIBILITY OF THE CONTRACTOR.
- ALL EXPOSED EARTH SURFACES MUST BE PROTECTED FROM WIND AND WATER EROSION PRIOR TO FINAL ACCEPTANCE OF ANY PROJECT.



LEGAL DESCRIPTION:


LOT A CORRECTED ESTATES TAYLOR RIDGE

NOTES:

- ALL SPOT ELEVATIONS REPRESENT FLOWLINE ELEVATION UNLESS OTHERWISE NOTED.
- ALL SLOPES SHALL BE 3:1 MAX. AND GRAVEL OR NATIVE SEEDING PRIOR TO CO.
- NO PONDING WITHIN 10' OF STRUCTURE
- SURVEY INFORMATION PROVIDED BY CONSTRUCTION SURVEY TECHNOLOGY UTILIZING NAVD 1988 DATUM

LEGEND

-----XXXXX-----	EXISTING CONTOUR
-----XXXXX-----	EXISTING INDEX CONTOUR
-----XXXXX-----	PROPOSED CONTOUR
-----XXXXX-----	PROPOSED INDEX CONTOUR
-----XXXXX-----	SLOPE TIE
+ XXXXX	EXISTING SPOT ELEVATION
+ XXXXX	PROPOSED SPOT ELEVATION
-----	LOT LINE
-----	CENTERLINE
-----	RIGHT-OF-WAY
-----	PROPOSED PVC SD (SEE PLAN FOR SIZE)
=====	EARTHEN SWALE
=====	EXISTING CURB AND GUTTER
=====	PROPOSED CMU SCREEN WALL-DESIGN BY OTHERS
=====	18" MAX RETAINING WALL PERIMETER WALL




WALL SHALL BE CONSTRUCTED SUCH THAT NO PORTION OF WALL OR FOOTING SHALL ENCR OACH INTO ADJACENT PROPERTIES UNLESS WRITTEN PERMISSION PROVIDED

WALL DETAILS AT ALL PROPERTY BOUNDARIES

CAUTION:

EXISTING UTILITIES ARE NOT SHOWN. IT SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR TO CONDUCT ALL NECESSARY FIELD INVESTIGATIONS PRIOR TO ANY EXCAVATION TO DETERMINE THE ACTUAL LOCATION OF UTILITIES & OTHER IMPROVEMENTS.



ENGINEER'S SEAL	5501 LA COLONIA DRIVE NW	DRAWN BY WCWJ
DAVID SOULE P.E. #14522	GRADING AND DRAINAGE PLAN	DATE 12-27-21
		2102100110-LAYOUT-12-27-21
		SHEET #
		JOB # 2102100110