City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	E14E002A	Project Name:	Spanish Walk Subdivision
NPDES Id. No.	NMR1006F1	Location:	410 Camino Espanol NW

8/8/2025	Owner	Contractor
Operator	Hakes Brothers Abq, LLC	
Contact name & title	Chris Hakes	
e-mail	chris@hakesbrothers.com	
Contact Phone #	505-650-9326	

COA Inspector	**Chancellor English**	Start/End Time:	12:45pm
Construction Phase:	Grading		

Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up

Weather at time of inspection?	Clear	Temperature: ~	95
Estimated date of last storm 0.25" or greater		7/3/2025	

Item Number	Deficiency/ Corrective Action			
1	None			
2.1	Discharge off site? (Y/N)	no		
4	Self Inspection Reports	No	Latest report Date:	N/A

Notes:
The perimeter walls and concrete trenches drain into two on-site ponds and prevent stormwater discharges off-site.

City of Albuquerque Stormwater Inspector Signature and date: 8/11/2025

Contact information: Chancellor English (505) 924-3325
cenglish@cabq.gov

Chancellor English