CITY OF ALBUQUERQUE



August 29, 2012

Gilbert Aldaz, P.E. **Applied Engineering & Survey** 1605 Blair Dr. NE Albuquerque, NM 87112 galdaz47@yahoo.com

Re: Gardner Zemke Addition, 6821 Academy Parkway West NE,

Request for Permanent C.O. - Not Accepted

Engineer's Stamp dated: 01-04-12, (E17/D001)

Certification dated: 08-22-12

Dear Mr. Aldaz,

Based upon the information provided in the Certification received 08-24-12, the above referenced Certification is <u>unacceptable</u> for release of a Permanent Certificate of Occupancy by Hydrology.

PO Box 1293

Albuquerque

- 1. It appears a six inch curb was constructed on the western property line in lieu of an eight inch curb. Please provide calculations demonstrating a six inch curb prevents flows from leaving the site.
- 2. Please certify the pond volume.
- 3. The Engineer's certifying language will need to be per the DPM, see enclosed.

NM 87103

If you have any questions, you can contact me at 924-3986.

www.cabq.gov

Sincerely,

Curtis A. Cherne, P.E.

Centra Cher

Principal Engineer—Hydrology, Planning Dept.

Development and Building Services

C: File

Enclosure (1)



DRAINAGE CERT W/ SURVEY WORK BY OTHERS 12/28/01

DRAINAGE CERTIFICATION

I,	RADED AND WILL DRAIN IN WITH THE DESIGN INTENT OF FORMATION EDITED ONTO THE BEEN OBTAINED BY IRM HE PROJECT SITE ON
BEST OF MY KNOWLEDGE AND BELIEF. THIS CERTIFICATIONS AND IS OF A REQUEST FOR	ION IS SUBMITTED IN SUPPORT
(DESCRIBE ANY EXCEPTIONS AND/OR QUALIFICATIO	
(DESCRIBE ANY DEFICIENCIES AND/OR REQUIRED CORRECTION PARAGRAPH)	CTIONS HERE IN A SEPARATE
THE RECORD INFORMATION PRESENTED HEREON IS NOT NECESSARILY COMPLETE AND INTENDED ONLY TO VERIFY SUBSTANTIAL COMPLIANCE OF THE GRADING AND DRAINAGE ASPECTS OF THIS PROJECT. THOSE RELYING ON THIS RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE USING IT FOR ANY OTHER PURPOSE.	
XXXXXXXXXXXXXXX, NMPE XXXX	(SEAL)
DATE	

APPROVED BY THE EXECUTIVE COMMITTEE ON 4//9/02