PLANS/PLATS ON FILE

FILE DESC: E-17/0015

PLANS/PLATS 2

Goldberg · Mann & Associates
Engineers·Planners
811 Pennsylvania St. Albuquerque, New Mexico 87110 (505) 265-3821

May 14, 1979

8-108

Mr. Bruno Conegliano
Asst. City Engineer/Hydrology
Division of Engineering
P.O. Box 1293
Albuquerque, New Mexico 87103

Re: SWECO Warehouse

Dear Bruno:

Transmitted herewith are four copies of the revised drainage plan for the SWECO Warehouse.

As per your request, on May 11, 1979, we have added the following:

1. An equalizer drain pipe between ponds
2. A drain pipe from Pond B into the gutter
3. A note directing the contractor not to line the ponds with plastic film
4. Delineated the drainage areas
5. Adjusted the swale along the north side of the property
6. Added the areas that contribute to each pond

Also as we discussed, a cutoff ditch has been constructed along the east property line. I do not know who constructed the ditch but it conveys runoff from the east to the south into Osuna. If the ditch should overflow and runoff enter the subject property, the runoff will be conveyed across the property as normal drainage and into the ponds.

If you have any further comments, do not hesitate to call. Thank you.

Yours truly,

GOLDBERG-MANN & ASSOCIATES

Thomas T. Mann, Jr., P.E.
President

PLAN/PLATS

ON

FILE