

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

October 29, 1992

James R. Topmiller, P.E.
Bohannon Huston, Inc.
7500 Jefferson NE
Albuquerque, N.M. 87109

RE: MASTER DRAINAGE PLAN FOR LOTS B & C ALBUQ INDUSTRIAL PARK (E-17/D34)
RECEIVED SEPTEMBER 23, 1992 FOR SITE DEV PLAN FOR SUB D APPROVAL
STAMPED & DATED 9-17-92

Dear Mr. Topmiller:


Based on the information included in submittal referenced above, City Hydrology approves the Ammended Master Drainage Plan; which was originally filed as "Nabisco Warehouse (E-17/D34)"; for Site Development Plan.

Before Building Permit approval, the following comments must be addressed:

1. Plans for individual basins must indicate how offsite flows from adjacent basins will be prevented.
2. Plans for individual basins must indicate how discharge from the basin will be limited to 2.1 cfs/acre.

If I can be of further assistance, you may contact me at 768-2727.

Sincerely,


John P. Curtin, P.E.
PWD/Hydrology

WPHYD+3742

PUBLIC WORKS DEPARTMENT

