

j arthur blessen engineering
architect engineer
2429 Zena Lona NE
(505) 293-1477
Albuquerque, NM 87112

March 16, 2015

Curtis Cherne, PE
City of Albuquerque Planning Department
PO Box 1263
Albuquerque, New Mexico 87103


file: E17/D034C
re: Array Technology Paving
City of Albuquerque Comments

Dear Mr. Cherne,

The size of detention Pond A has been increased to provide a portion of the pond below the discharge to retain the first flush volume of the added impervious area associated with paving the storage yard area. (See attached drawings).

There are no new landscaped areas associated with the proposed pavings.

Should you have any questions or require addition information please call.



J Arthur Blessen PE

POND A - FIRST FLUSH REQUIREMENTS PROPOSED IMPROVED AREA
 BASINS B-3, AND C-1
 ADDITIONAL IMPERVIOUS AREA (D) = 22,140 SF
 VOL (ff) = 22,140 * 0.34" / 12 = 627 CF



D2 $\frac{F}{3}$

1

