

CITY OF ALBUQUERQUE



March 11, 2015

J. Arthur Blessen, P.E.
J. Arthur Blessen Engineering
2429 Zena Lona NE
Albuquerque, NM 87112

**RE: Array Technologies Paving
3901 Midway PL NE
Grading and Drainage Plan
Engineers Stamp Date 2/23/2015 (E17D034C)**

Dear Mr. Blessen,

Based upon the information provided in your submittal received 2/25/2015, the above referenced Grading and Drainage Plan cannot be approved for Grading Permit or Paving Permit until the following comments are addressed.

- Mention of the first flush per EPA standards is required and placed on the plans. The amount required for detention is .34" times the new impervious area. Depress the landscape islands/areas as part of the first flush requirements.

PO Box 1293

If you have any questions please contact me at 924-3986 or Rudy Rael at 924-3977.

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Hydrology
Planning Department

RR/CC
C: File