

CITY OF ALBUQUERQUE



May 23, 2016

David Soule, P.E.
Rio Grande Engineering
9171 Glendale Ave NE
Albuquerque, NM 87122

**Re: Independence Square
Erosion and Sediment Control Plan
Engineer's Stamp Date plan 2-5-16, 5-23-16 detail sheet 5-23-16 (E17E076)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 3-1-16 and 5-23-16 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit-Building Permit with the following conditions:

1. It is understood that the legend item for "Proposed Storm Inlet" implies inlet protection. Please clarify on future submittals.
2. The outlet for the pond has a sediment BMP.

PO Box 1293

Include a copy of the approved plan(s) in the Building Permit set.

Albuquerque

The plan cannot be approved for Work Order until the following comment is addressed:

New Mexico 87103

1. The information sheet requested Construction Plan Work Order approval; however, the scope of the Construction Plan Work Order is not included and is not clear.

If you have any questions, you can contact me at 924-3420.

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email