

CITY OF ALBUQUERQUE



May 23, 2016

David Soule, P.E.
Rio Grande Engineering
9171 Glendale Ave NE
Albuquerque, NM 87122

**Re: Independence Square
Erosion and Sediment Control Plan
Engineer's Stamp Date 5-23-16 (E17E076)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 5-23-16 the above referenced plan is not approved to be included in the SWPPP or for ESC Permit-Building Permit or Work Order until the following comments are addressed:

1. The plan submitted only shows the connection to the Pino Arroyo and did not address comment #2 from the last letter "Storm inlets are shown, but inlet protection is not specified and comment #3 "A Curb Storm Drain Inlet Filter" is shown, but the inlets appear to be "at grade" not in a curb."
2. The entire plan (site and connection to the Pino arroyo) should be resubmitted.
3. The information sheet requested Construction Plan Work Order approval; however, the scope of the Construction Plan Work Order is not included and is not clear.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email