



**Planning Department  
Transportation Development Services Section**

March 26, 2014

Tafazzul Hussain, A.I.A.  
Afra Construction & Design, LLC  
2501 Yale Blvd. SE, Suite 102  
Albuquerque, NM 87106

**Re: San Antonio Commons, 5700 San Antonio Dr. NE**  
**Certification Submittal for CO – Transportation Development**  
Engineer's/Architect's Stamp dated 8-07-08 (E18-D059)  
Certification dated 3-25-14

Dear Mr. Hussain,

The Letter of Certification submitted on 3-25-14 is not sufficient for acceptance by this office for final Certificate of Occupancy (C.O.). The following items need to be addressed:

- The ADA accessible parking spaces did not have signs hung.
- The crosswalk connecting Building B to the Pino Arroyo Path needs to be defined by striping or stamped concrete.
- Redline any crosswalks that have not been installed in submittal.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

Resubmit acceptable package along with fully completed Drainage Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation. For minor comments and/or repairs, please submit photos to [rmichel@cabq.gov](mailto:rmichel@cabq.gov) prior to submittal.

Sincerely,

Racquel M. Michel, P.E.  
Senior Engineer, Planning Dept.  
Development and Building Services

C: File