

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

August 23, 2022

505 Solutions, LLC. – Rachel Bevan, rachelbevan06@gmail.com

Sites: ABQ Ranch Estates Unit II - E22E002 - NMR1004JQ

Re: Drainage Ordinance (14-5-2-11) Violations for Erosion and Sediment Control

Sediment was first observed during a City compliance inspection on 8/4/22 and then again during a follow-up inspection on 8/19/22. The following violations were observed on 8/19/22. A combination of street sweeper and water truck had been used to push the sediment around rather than to pick it up.





Piles of sediment begin inside the private gated community at McKay Way,



CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

with tracks leading all of the way to the intersection of Spain and Royal Oak Dr.



Sediment deposited at the intersection of Royal Oak St and Royal Oak Dr., and at





The intersection of Royal Oak St and Royal Oak Ave.



CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

Albuquerque's Erosion and Sediment Control (ESC) ordinance § 14-5-2-11 at link https://codelibrary.amlegal.com/codes/albuquerque/latest/albuquerque_nm/0-0-0-19897 requires the property owner to comply with the Construction General Permit (CGP) [2022 Construction General Permit \(CGP\) | US EPA](#).

Required Mitigation:

1. Where sediment has been tracked-out from your site onto paved roads and sidewalks remove the deposited sediment by the end of the same business day CGP 2.2.4.d, and implement additional track-out controls as necessary to ensure that sediment removal occurs prior to vehicle exit CGP 2.2.4.c.

If all of the violations are not mitigated within seven days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance, and the non-compliance will be reported to the EPA. Repeat violations are also subject to a fine of \$500/day.

If you have any questions, you can contact me at 924-3420, jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Hydrology/Stormwater Quality
Planning Dept.