

**5. ALL EXPOSED EARTH SURFACES
WATER EROSION PRIOR TO FINAL /**

NEW MEXICO STATE PLANE-CENTRAL ZONE

- ① Grades within 2 in fall must slope to road & missing 5875 contour
- ② Clarify Grades and easement at east R. show that will not be too low structures
- ③ 5875 Contour at east appears to be significant
- ④ what is the hearing date east & south R?
- ⑤ Cobble swale sketched R appears to channel (Front yard & driveway) narrow path again which also appears at narrowest point a) check grades for b) provide detail & swale away from driveway
- ⑥ Grading @ NW corner different from that approved recently. 1'-2' cut at a local by a Power Transformer
- ⑦ Drainage toward Back of lot - not side of lot

