

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

September 15, 2023

Genevieve L. Donart, P.E.
Isaacson & Arfman Inc.
128 Monroe St. NE
Albuquerque, NM 87108

Re: Allaso High Desert/ 6701 Tennyson St. NE PHASE 5/BUILDING 6
Request for Certificate of Occupancy
Transportation Development Final Inspection
Architect's Stamp dated 12-15-2020 (E22-D023)
Certification dated 09-13-23

Dear Ms. Donart,

Based upon the information provided in your submittal received 09-14-22, Transportation Development has no objection to the issuance of a Permanent Certificate of Occupancy. This letter serves as a "green tag" from Transportation Development for a Permanent Certificate of Occupancy to be issued by the Building and Safety Division.

PO Box 1293

If you have any questions, please contact Ernest Armijo at (505) 924-3991 or at earmijo@cabq.gov

Albuquerque

Sincerely,

NM 87103

Ernest Armijo, P.E.
Principal Engineer, Planning Dept.
Development Review Services

www.cabq.gov

\xxx via: email
C: CO Clerk, File



City of Albuquerque

Planning Department

Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET

SEE NEXT

Project Title: Allaso High Desert **Building Permit #** PAGE **Hydrology File #** E22D023

DRB# PR-2020-004368 **EPC#** PR-2020-004086

Legal Description: Tract 1, The Foothills **City Address OR Parcel** 6701 Tennyson St NE, 87111

Applicant/Agent: Isaacson & Arfman, Inc. **Contact:** Genevieve Donart

Address: 128 Monroe St NE **Phone:** 505-268-8828

Email: gennnyd@iacivil.com

Applicant/Owner: Titan Tennyson, LLC **Contact:** Josh Rogers

Address: 6300 Riverside Lane NW, Ste. 200, Albuquerque, NM 87120 **Phone:** 505-515-2914

Email: jrogers@titan-development.com

TYPE OF DEVELOPMENT: ___ PLAT (#of lots) ___ RESIDENCE ☒ DRB SITE ___ ADMIN SITE: ___

RE-SUBMITTAL: ___ YES ☒ NO

DEPARTMENT: ☒ TRANSPORTATION ___ HYDROLOGY/DRAINAGE

Check all that apply:

TYPE OF SUBMITTAL:

- ☒ ENGINEER/ARCHITECT CERTIFICATION
- ☐ PAD CERTIFICATION
- ☐ CONCEPTUAL G&D PLAN
- ☐ GRADING PLAN
- ☐ DRAINAGE REPORT
- ☐ DRAINAGE MASTER PLAN
- ☐ FLOOD PLAN DEVELOPMENT PERMIT APP.
- ☐ ELEVATION CERTIFICATE
- ☐ CLOMR/LOMR
- ☐ TRAFFIC CIRCULATION LAYOUT (TCL) ADMINISTRATIVE
- ☐ TRAFFIC CIRCULATION LAYOUT FOR DRB APPROVAL
- ☐ TRAFFIC IMPACT STUDY (TIS)
- ☐ STREET LIGHT LAYOUT
- ☐ OTHER (SPECIFY)
- ☐ PRE-DESIGN MEETING?

TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- ☐ BUILDING PERMIT APPROVAL
- ☒ CERTIFICATE OF OCCUPANCY **BLDG 6**
- ☐ CONCEPTUAL TCL DRB APPROVAL
- ☐ PRELIMINARY PLAT APPROVAL
- ☐ SITE PLAN FOR SUB'D APPROVAL
- ☐ SITE PLAN FOR BLDG PERMIT APPROVAL
- ☐ FINAL PLAT APPROVAL
- ☐ SIA/RELEASE OF FINANCIAL GUARANTEE
- ☐ FOUNDATION PERMIT APPROVAL
- ☐ GRADING PERMIT APPROVAL
- ☐ SO-19 APPROVAL
- ☐ PAVING PERMIT APPROVAL
- ☐ GRADING PAD CERTIFICATION
- ☐ WORK ORDER APPROVAL
- ☐ CLOMR/LOMR
- ☐ FLOOD PLAN DEVELOPMENT PERMIT
- ☐ OTHER (SPECIFY) _____

DATE SUBMITTED: 09/13/23

Date: September 13, 2023

Project: Allaso High Desert (E22D023)

Subject: Rolling TCL Certification: Phase 5

TRAFFIC CERTIFICATION

I, Genevieve L. Donart, PE, NMPE No. 15088, of the firm Isaacson & Arfman, P.A., hereby certify that Phases 1 & 2 of this project are in substantial compliance with and in accordance with the design intent of the DRB approved plan dated 12/15/2020. The record information edited onto the original design document has been obtained by Robert J. Fierro, NMPLS No. 22909 of the firm Fierro & Company, LLC. I further certify that I or someone under my direct supervision visited the project site on September 12, 2023 and have determined by visual inspection that the survey data provided is representative of actual site conditions and is true and correct to the best of my knowledge and belief.


This certification is submitted in support of a request for Permanent Certificate of Occupancy.

The record information presented hereon is not necessarily complete and intended only to verify substantial compliance of the traffic aspects of this project. Those relying on the record document are advised to obtain independent verification of its accuracy before using it for any other purpose.

The following items are required to be completed with future phases:

1. Install parking stall striping along the eastern portion of the north wall with Building 7 (Phase 6)
2. Install parking stall striping north of Building 8 (Phase 7)
3. Install parking stall striping in front of Building 9 (Phase 8)
4. Install parking stall striping in front of Building 10 with that building. (Phase 9.)
5. Install parking stall striping in front of Building 11 with that building. (Phase 10.)
6. Install parking stall & pedestrian crossing striping in front of Building 12 with that building. (Phase 11.)
7. Install parking stall striping in front and to the south of Building 13 with that building. (Phase 12.)
8. Install parking stall & pedestrian crossing striping in front and to the south of Building 14 with that building. (Phase 13.)

Sincerely,
Isaacson & Arfman, Inc.



Genevieve L Donart, NMPE No. 15088

ALLASO HIGH DESERT

HYDROLOGY FILE #E22D023

PHASING/BUILDING PERMIT NUMBERS

PHASE #	BLDG #	PERMIT #
1	1	BP-2021-08158
1	2	BP-2021-20831
1	19	BP-2021-20851
2	4	BP-2021-20821
3	3 NORTH	BP-2021-20815
3	3 SOUTH	BP-2021-20818
4	5	BP-2021-20822
5	6	BP-2021-20825
6	7	BP-2021-20827
7	8	BP-2021-20829
8	9	BP-2021-20831
9	10	BP-2021-20834
10	11	BP-2021-20838
11	12	BP-2021-20840
12	13	BP-2021-20841
13	14	BP-2021-20842
14	18	BP-2021-20849
15	17	BP-2021-20848
16	16	BP-2021-20845
17	15	BP-2021-20844

TRAIL NOTES

- MAINTENANCE OF THE SOFT-SURFACE PATHWAY LOCATED WITHIN THE SAN ANTONIO DRIVE RIGHT-OF-WAY ABUTTING THE NORTH PROPERTY LINE OF TRACT 1 AND WITHIN THE 5-FOOT PUBLIC PEDESTRIAN TRAIL EASEMENT GRANTED BY THIS PLAT SHALL BE THE RESPONSIBILITY OF THE OWNER OF TRACT 1.
- THE CRUSHER FINES PATH WILL FOLLOW FOREST SERVICE/IMBA SUSTAINABLE DESIGN STANDARDS AND "THE OSD TRAIL AND TRAILHEAD DESIGN STANDARDS FOR OPEN SPACE" TO ALLOW FOR QUALITY AND CONFORMITY OF OPEN SPACE TRAILS IN THE CITY.
- THE GRADE OF THE TRAIL WILL BE HALF OR LESS OF THE SIDE SLOPE OF THE TRAIL AND ROCK RETAINING WALLS WILL BE ADDED IF NECESSARY.
- THE TRAIL CONNECTION IS NOT INTENDED TO BE ACCESSIBLE PER THE AMERICAN DISABILITIES ACT BECAUSE IT MEETS THE CONDITION "WHERE COMPLIANCE WOULD SUBSTANTIALLY ALTER THE FUNCTION OR PURPOSE OF THE FACILITY OR THE SETTING". IN ADDITION TO THE SLOPE, A PARKING AREA IS NOT POSSIBLE AT THIS LOCATION.
-

LIGHTING LEGEND

SYMBOL	DESCRIPTION
P1	SINGLE HEAD, POLE MOUNTED FULLY CUT-OFF LIGHTING FIXTURE WITH LED LAMPS, TYPE III DISTRIBUTION, 3000K, B.O.F. @ +15'-0" AFG
2P1	DOUBLE HEAD, POLE MOUNTED FULLY CUT-OFF LIGHTING FIXTURE WITH LED LAMPS, TYPE III DISTRIBUTION, 3000K, B.O.F. @ +15'-0" AFG
W1	WALL MOUNTED FULLY CUT-OFF LIGHTING FIXTURE WITH LED LAMPS, 3000K AND TYPE III DISTRIBUTION, T.O.F. @ 10'-0" AFG
W2	DECORATIVE WALL MOUNTED LIGHTING FIXTURE WITH LED LAMPS, 3000K ADA COMPLIANT, T.O.F. @ 7'-0" AFG
PT	POST MOUNTED FULLY CUT-OFF LIGHTING FIXTURE WITH LED LAMPS, 3000K AND TYPE V DISTRIBUTION, T.O.F. @ 10'-0" AFG
CA	4 FT. LED LENSED CARPORT LIGHT, (1) 20W LED, 3000K AND 80CRI, U.L. LISTED FOR DAMP LOCATIONS.
NOTES:	
T.O.F. - TOP OF FIXTURE	
B.O.F. - BOTTOM OF FIXTURE	
AFG - ABOVE FINISHED GRADE	

SITE LEGEND

	DENOTES PROPERTY LINE
	DENOTES ACCESSIBLE PARKING
	FIRE HYDRANT
	NO. OF PARKING SPACES IN A ROW
	NO. OF CARPORT SPACES

DEVELOPMENT DATA

LEGAL DESCRIPTION:

TRACT 1, THE FOOTHILLS

LOT AREA:

NET: 699,323 SF 16.054 acres

ZONING:

CURRENT: R-MH
LAND USE: MULTI-FAMILY RESIDENTIAL

CONSTRUCTION TYPE:

PROVIDED: VA & VB

AMENITIES:

POOL, SPA, FITNESS, RECREATION CLUB ROOM, RAMADAS, CABANAS, BBQ

SETBACKS:

PROVIDED:	PARKING	BUILDING
FRONT (SOUTH):	5'-0"	5'-0"
SIDE (EAST):	6'-4"	10'-0"
SIDE (WEST):	82'-9"	39'-1"
REAR (NORTH):	15'-0"	73'-6"

* VARIANCE OF 10 FEET TO THE 15-FOOT MINIMUM FRONT SETBACK APPROVED BY EPC UNDER APPLICATION NUMBER: VA-2020-00244

BLDG HEIGHT:

ALLOWED: 45 FEET

UNIT MIX:

UNIT GARDEN	
1 Bedroom	72
2 Bedroom	108
3 Bedroom	24
UNIT GARDEN	204
UNIT TH	
1 Bedroom	38
2 Bedroom	37
3 Bedroom	2
UNIT TH	77
TOTAL UNITS	281

- ALL GROUND FLOOR UNITS IN BLDGS TYPE 1 AND TYPE 2 SHALL BE OF AT LEAST ANSI TYPE 'B' ACCESSIBILITY STANDARDS.
- ALL UNITS IN OTHER BLDGS ARE MULTI-STORY UNITS AND EXEMPT FROM ACCESSIBILITY REQUIREMENTS.
- 2% OF TOTAL UNITS TO BE ANSI TYPE 'A' ACCESSIBILITY STANDARDS.

DENSITY:

PROPOSED: 17.50 D.U. / ACRE

KEYNOTES


- 8.5x18' PARKING SPACE WITH 2' OVERHANG, TYPICAL. SEE DETAIL 1/A1.20.
- 10x20' PARALLEL PARKING SPACE.
- 11x18' ACCESSIBLE PARKING SPACE WITH 2' OVERHANG, SEE DETAIL 6/A1.20.
- ACCESSIBLE CURB RAMP. SEE DETAIL 5/A1.20.
- 6' WIDE ACCESSIBLE DRIVEWAY CROSSING WITH STAMPED COLOR ASPHALT.
- 5' WIDE ACCESSIBLE DRIVEWAY CROSSING WITH STAMPED COLOR ASPHALT.
- INDICATES LOCATION OF CARPORT PARKING STRUCTURE, SEE DETAIL 8/A1.20.
- TRASH YARD WITH 8' TALL CMU WALL WITH STUCCO FINISH PAINTED TO MATCH BUILDING 2 COMPACTORS (ONE FOR TRASH AND ONE FOR RECYCLE). SEE DETAIL 56/A1.22.
- VEHICULAR SWING GATE. SEE DETAIL 22/A1.21.
- GATE CONTROL BOX AND SITE DIRECTORY MAP.
- EMERGENCY ONLY ACCESS GATE, PROVIDE KNOX KEY PER FIRE DEPARTMENT REQUIREMENTS, SIGN READING "EMERGENCY VEHICLES ONLY" TO BE PROVIDED ON EACH SIDE OF THE GATE.
- PEDESTRIAN GATE, SEE DETAIL 20/A1.21.
- WROUGHT IRON PERIMETER VIEW FENCE, SEE DETAIL 11/A1.20. REFER TO CIVIL DRAWINGS FOR RETAINING CONDITIONS. SEE DETAIL 10/A1.20. WALLS/FENCES WILL COMPLY WITH 5-7(D).
- 6' SIDEWALK WITH 2% MAX. CROSS-SLOPE, TYPICAL AT PARKING, SEE DETAIL 9/A1.20.
- 4' SIDEWALK WITH 2% MAX. CROSS-SLOPE, TYPICAL AT INTERIOR SITE.
- 6' CLEAR SIDEWALK WITH 2% MAX. CROSS-SLOPE, CONNECTING ACCESSIBLE PARKING, PUBLIC WAY, AND MAIN LEASING ENTRANCE.
- NEW 6' SIDEWALK, WITH 2% MAX. CROSS-SLOPE, TO CONNECT TO EXISTING STREET SIDEWALK ON TENNYSON STREET.
- NEW TENNYSON STREET ALIGNMENT.
- MOUNTABLE CURB FOR EMERGENCY ACCESS, SEE DETAIL 30/A1.21.
- PROJECT SIGN MOUNTED ON BUILDING.
- 24"x24" CMU PLASTER AT WROUGHT IRON FENCE, PLASTER TO BE SPACED 50" MAX. ON CENTER, SEE DETAIL 12/A1.20. WALLS/FENCES WILL COMPLY WITH 5-7(D).
- 8.5x18' PARKING SPACE WITH WHEEL STOP INFRONT OF LEASING BUILDING.
- 11x18' ACCESSIBLE PARKING SPACE WITH WHEEL STOP INFRONT OF LEASING BUILDING.
- BICYCLE PARKING RACKS, SEE DETAIL 23/A1.21.
- "EV" INDICATES LOCATION OF PARKING SPACE WITH ELECTRIC VEHICLE CHARGING STATION.
- PEDESTRIAN ACCESSIBLE RAMP TO COMPLY WITH ANSI AND ADA STANDARDS, WITH HANDRAILS ON BOTH SIDES AND A 8.33% MAX SLOPE. SEE DETAILS 48,50&56/A1.23.
- FIRE TRUCK TURN AROUND.
- AMAFCA MAINTENANCE ROAD.
- CRUSHER FINES TRAIL PATH WITH 2% MAX. CROSS-SLOPE. SEE DETAIL 60/A1.23 AND TRAIL NOTES ON THIS PAGE.
- 5' WIDE CURB CUT FOR TRAIL.
- PROVIDE (2) SPEED BUMP AT WEST DRIVE, SEE DETAIL 51/A1.23.
- SPEED BUMP SIGN ON EACH SIDE FACING TRAFFIC, SEE DETAIL 54/A1.23.



ZONE ATLAS E-22

VICINITY MAP

NOT TO SCALE



PROJECT NUMBER: PR-2020-004086
Application Number: SI-2020-00690

This Plan is consistent with the specific Site Development Plan approved by the Environmental Planning Commission (EPC), dated 9/10/2020, and the Findings and Conditions in the Official Notification of Decision are satisfied.

Is an Infrastructure List required? () Yes () No. If yes, then a set of approved DRC plans with a work order is required for any construction within Public Right-of-Way or for construction of public improvements.

DRB SITE DEVELOPMENT PLAN SIGNOFF APPROVAL:

<u>Jeanne Wolfenbarger</u>	Jan 12, 2021
Jeanne Wolfenbarger (Jan 12, 2021 15:45 MST)	Date
Traffic Engineering, Transportation Division	
<u>Joe Galt</u>	Jan 14, 2021
Joe Galt	Date
ABCWUA	
<u>Chris Ammerfeldt</u>	Jan 13, 2021
Chris Ammerfeldt (Jan 13, 2021 21:34 MST)	Date
Parks and Recreation Department	
<u>Ernest Arriaga</u>	Jan 12, 2021
Ernest Arriaga	Date
City Engineer	

<u>Herman Gallegos</u>	12-15-20
Herman Gallegos	Date
<u>Carl Garcia</u>	Jan 12, 2021
Carl Garcia (Jan 12, 2021 13:46 MST)	Date
Code Enforcement	
<u>Jan 25, 2021</u>	Jan 25, 2021
DRB Chairperson, Planning Department	Date

ALLASO HIGH DESERT

6701 TENNYSON STREET N.E., 87111
ALBUQUERQUE, NEW MEXICO

Office of Rich Barber
ORB Architecture, Inc.
WorldHQ@ORBArch.com



TITAN
DEVELOPMENT

Contractor must verify all dimensions at project before proceeding with this work.
Do not reproduce these drawings and specifications without the expressed written permission of the Architect. The drawings and specifications are instruments of service and shall remain the property of the Architect whether the project for which they are made is executed or not. These drawings and specifications shall not be used by anyone on any other projects, for additions to this project, or for completion of this project by others except by the expressed written permission of the Architect.
© ORB Architecture, LLC 2019

REVISIONS/SUBMITTALS


DATE	DESCRIPTION
------	-------------

DRB SUBMITTAL

DATE: DECEMBER 15, 2020 ORB #: 19-209

A1.10

SITE PLAN



**ALLASO
HIGH DESERT**
6701 TENNYSON STREET N.E., 87111
ALBUQUERQUE, NEW MEXICO

Office of Rich Barber
ORB
Architecture, P.C.
WorldHQ@ORBArch.com



Contractor must verify all dimensions at project before proceeding with this work.
Do not reproduce these drawings and specifications without the expressed written permission of the Architect. The drawings and specifications are instruments of service and shall remain the property of the Architect whether the project for which they are made is executed or not. These drawings and specifications shall not be used by anyone on any other projects, for additions to this project, or for completion of this project by others except by the expressed written permission of the Architect.

© ORB Architecture, LLC 2019

REVISIONS/SUBMITTALS
DATE DESCRIPTION

2 05/07/2021 1ST CITY COMMENTS

2ND BUILDING SUBMITTAL
DATE: MAY 07, 2021 ORB #: 19-209

A1.11
PHASING SITE PLAN