

CITY OF ALBUQUERQUE



October 24, 2013

Jeffrey G. Mortensen, P.E.
High Mesa Consulting Group
6010-B Midway Park Blvd NE
Albuquerque, NM 87109

**Re: Chaparral E.S., Parent Parking Lot
Grading and Drainage Plan, 3625 Milne Rd. NW
Engineer's Stamp dated 09-18-2013 (F-10/D005)**

Dear Mr. Mortensen,

Based upon the information provided in your submittal dated 09-19-13, the above referenced Grading and Drainage plan cannot be approved for building permit based on the following comments:

- Provide capacity calculation for the Beehive Grate. Please use a 50% clogging factor in your calculations. The grate may have to be lowered to avoid overflow.
- Modify the grading plan if the Beehive Grate must be lowered.

If you have any questions, you can contact me at 924-3695.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: email