

CITY OF ALBUQUERQUE



March 4, 2019

Lelan Morrison, CPESC
Inspections Plus Inc.
805 Nikanda Rd NE
Albuquerque, NM 87107

**Re: PRESNow on Coors
Erosion and Sediment Control Plan
CPESC Stamp Date 2-20-19 (F11E019)**

Dear Mr. Morrison,

Based upon the information provided in your submittal received 2-28-19, the above referenced plan is approved to be included in the SWPPP and for NOI documentation review for grading and Building Permit with the following condition:

1. The drains for the roof flows will require inlet protection, between the time they are installed to the time they are connected to the drains from the roof.

PO Box 1293

If you have any questions, you can contact me at 924-3420.

Albuquerque

Sincerely,

NM 87103

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

www.cabq.gov

C: email