



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	F13E028A	Project Name:	Griegos Farms
NPDES Id. No.	NMR1005G7	Location:	1860 Griegos Rd NW
6/6/2024	Owner	Contractor	
Operator	Griegos Farms, LLC	Guzman Construction Solutions	
Contact name & title	Jay Rembe	Tyler Richter	
e-mail	rembe@rembedesign.com	tyler@guzmancs.com	
Contact Phone #	505-453-7164	505-452-0663	
COA Inspector	Chancellor English	Start/End Time:	130pm
Construction Phase:	beginning verticals		
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25" <input type="checkbox"/> 311/Complaint <input type="checkbox"/> Follow Up
Weather at time of inspection?	Clear	Temperature: ~	90
Estimated date of last storm 0.25" or greater	4/1/2024		

Item Number	Deficiency/ Corrective Action		
1	Permit Coverage posting is not visible from the road in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site. The notice must be located so it is visible from the public road that is nearest to the active part of the construction site per CGP Part 1.5.		
2	The perimeter silt fence is in need of repair in violation of CGP Part 2.1.4. Required mitigation: Ensure all stormwater controls are maintained and remain in effective operating condition during permit coverage and are protected from activities that would reduce their effectiveness per CGP Part 2.1.4.		
3	There was concrete washout on bare soil and not in the provided washout container in violation of CGP Part 2.3.4. Required mitigation: Direct wash water into a leak-proof container or leak-proof and lined pit designed so no overflows can occur due to inadequate sizing or precipitation and do not allow liquid wastes to be disposed of through infiltration or to otherwise be disposed of on the ground per CGP Part 2.3.4.		
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	Yes	Latest report Date: 5/29/2024

Notes:	
Called contact to review SWPPP	

City of Albuquerque Stormwater Inspector Signature and date: 6/12/2024
Contact information: Chancellor English (505) 924-3325
english@cabq.gov

Chancellor English