



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	F13E028A	Project Name:	Griegos Farms		
NPDES Id. No.	NMRT005G7	Location:	1860 Griegos Rd NW		
12/11/2024	Owner	Contractor			
Operator	Griegos Farms, LLC	Guzman Construction Solutions			
Contact name & title	Jay Rembe	Tyler Richter			
e-mail	<a href="mailto:rembe@rembedesign.com">rembe@rembedesign.com</a>	<a href="mailto:tyler@guzmancs.com">tyler@guzmancs.com</a>			
Contact Phone #	505-453-7164	505-452-0663			
COA Inspector	Chancellor English	Start/End Time:	11am		
Construction Phase:	beginning verticals				
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	Clear		Temperature: ~	45	
Estimated date of last storm 0.25" or greater	11/7/2024				
Item Number	Deficiency/ Corrective Action				
1	The SWPPP has not been certified by either operator (Griegos Farms, LLC or Guzman Construction Solutions) in violation of CGP Part 7.2.10. Required mitigation: Your signatory must sign and date your SWPPP in accordance with Appendix G, Part G.11.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Yes	Latest report Date:	11/8/2024	

Notes:	
SWPPP in doc-box mounted on the back of posting. Trenches along the perimeter with block walls and basins throughout the site limit discharge from the site.	
Previous violations for washout, BMPs, and posting have been mitigated.	
A Delegation of Authority has not been completed by the Griegos Farms, LLC NOI certifier.	

City of Albuquerque Stormwater Inspector Signature and date: 12/12/2024  
Contact information: Chancellor English (505) 924-3325  
[cenglish@cabq.gov](mailto:cenglish@cabq.gov)

Chancellor English