

CITY OF ALBUQUERQUE



August 14, 2012

Edward J. Losinki, P.E.
JEL & Associates, LLC
250 Bazan Loop
Corrales, NM 87048

jelassoc@comcast.net

Re: Car Crafters, 5404 Edith NE,
Request for Permanent C.O. – Not Accepted
Engineer's Stamp dated: 12-21-11, (F15/D036)
Certification dated: 08-11-12

Dear Mr. Losinki,

Based upon the information provided in the Certification received 08-08-12, the above referenced Certification is **unacceptable** for release of a Permanent Certificate of Occupancy by Hydrology.

PO Box 1293

1. The eastern slope will require Shot-Crete per keyed note #1.
2. The plan should reflect current site conditions. Please indicate all details not constructed and show which keyed notes that are deleted or not used.

Albuquerque

If you have any questions, you can contact me at 924-3695.

NM 87103

Sincerely,

Shahab Biazar, P.E.
Senior Engineer—Hydrology, Planning Dept.
Development and Building Services

www.cabq.gov

C: File