

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Interim Director



Mayor Timothy M. Keller

March 15, 2022

Mathew Vallejos
Green Globe Environmental, LLC
PO Box 400
Los Lunas NM, 87031

**Re: ABCWUA Backfill Screening Site – 5408 2nd St NW
Erosion and Sediment Control Plan
Engineer's Stamp Date 3/9/2022 (F15E056)**

Dear Mr. Vallejos,

Based upon the information provided in your submittal received 3/9/2022, the above referenced plan can't be approved until the following comments are addressed.

1. How will the site satisfy the Final Stabilization Criteria in CGP 2.2.14 before the project end date in the Low Erosivity Waiver (LEW)? If the site can't be stabilized in the time frame, then NPDES coverage is required.
2. The SWPPP must include site-specific interim and permanent stabilization per CGP 9.4.1.c.i. The Landscape Plan can be used to satisfy this requirement and should be submitted separate from the ESC Plan with the application to the Stormwater Quality Section of the Planning Department and they should be included in the SWPPP. Provide a specification on the ESC Plan for any disturbed areas not covered by the Landscape Plan.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services