



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	F16E001A	Project Name:	Maverik - 19054 ABQ NM
NPDES Id. No.	NMR10032O	Location:	3601 Montgomery Blvd. NE
5/20/2021	Owner	Contractor	
Operator	Maverik	Enterprise Builders	
Contact name & title	Lance Dunkley	David Lundsten	
e-mail	lance.dunkley@maverik.com	dlundsten@ebnm.com	
Contact Phone #	801-683-3960	505-452-7639	
COA Inspector	Thomas Evans	Start/End Time:	3:15 PM/3:35 PM
Construction Phase:	Building Construction		
Type of Inspection:	☒ Regular	☐ Storm Event	☐ Past Storm Event >0.25"
		☐ 311/Complaint	☐ Follow Up
Weather at time of inspection?	clear	Temperature:	~ 88
Estimated date of last storm 0.25" or greater	5/3/2021		
Item Number	Deficiency/ Corrective Action		
1	Inspection reports not in SWPPP. Maintain copies of the self-inspection reports on site in the SWPPP (CGP 4.7.3). Self-inspection reports shall be signed by an authorized representative per CGP 4.7.2 (Appendix I, section I.11.2		
2			
3			
4			
5			
2.1	Discharge off site? (Y/N)	no	
4	Self Inspection Reports	Requested	Latest report Date: 5/19/2021

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 05/21/2021