

CITY OF ALBUQUERQUE



August 10, 2015

Ronald Bohannon, P.E.
Tierra West, LLC
5571 Midway Park Pl NE
Albuquerque, NM 87109

**Re: Tract 2A1B Renaissance Center
Erosion Sediment Control Plan
Engineer's Stamp Date 7-31-15 (F16E013A)**

Dear Mr. Bohannon,

Based upon the information provided in your submittal received 7-31-15 the above referenced plan is approved to be included in the SWPPP and for Grading Permit/Building Permit once Hydrology has approved the grading plan with the following informational comments:

1. For the construction entrance, consider using 3"-6" stone rather than 2"-3" stone. The larger size will create more bounce.
2. A wattle may work better than silt fence for inlet protection as it is more permeable.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

C: email