



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name and Location	Behavioral Health Hospital 1525 Renaissance Blvd NE		
Site Contact Name & Agency	Daniel Pruitt Jayne 505-270-9246	ESC File No. NPDES ID No.	F16E051A NMR1001R6 NMR1001GN
Date of Inspection	12-5-18	Start/End Time	9:50/10:50
COA Inspector Name	Curtis Cherne, Stormwater Quality		
Describe Present Phase of Construction	Grading		
Type of Inspection:	<input checked="" type="radio"/> Regular • During storm event • Post-storm event (> 0.25 inch) • 311 / Complaint Response • Follow-Up		

Weather Information

Weather at time of this inspection?	Temperature: ~ 30 F°
<input checked="" type="radio"/> Clear • Cloudy • Rain • Sleet • Fog • Snowing • Windy	
Has there been a storm event since the site was Permitted?	• Yes • <input checked="" type="radio"/> No
Amount:	• < 1/4" • 1/4" to 3/4" • > 3/4" • Snow _____"

Inspection

CGP ¹ Section	BMP / Activity	Maintenance or Corrective Action Required	Location and Notes
1.5	Post a Notice		
2.2.1	Provide and maintain Natural buffer when Waters of the US < 50 ft		
2.2.3	Sediment control along any perimeter	✓	no silt fence east of entrance Green Globe installed west of entrance
2.2.3	Sediment control along any perimeter	✓	no silt fence west side ①
2.2.3	Sediment control along any perimeter	✓	no silt fence north side ①
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.4	Minimize sediment track-out	✓	installing pad while there

① Green Globe is staying BMPs while the site

2.2.5	Manage stockpiles		
2.2.6	Minimize Dust		
2.2.10	Protect Storm Drain Inlets		
2.2.10	Protect Storm Drain Inlets		
2.2.11	Minimize erosion of conveyance channels		
2.2.12	Sediment Basins		
2.2.14	Stabilize exposed portions of the site.		
2.2.14	Stabilize exposed portions of the site.		
2.2.14	Stabilize exposed portions of the site.		
2.2.14	Stabilize exposed portions of the site.		
2.3.1	Equipment and Vehicle Fueling		
2.3.2	Equipment and Vehicle Washing		
2.3.3	Building Material Storage		
2.3.3	Fuel, oil, hydraulic fluid, petroleum products and chemical storage		
2.3.3	Construction and Domestic Wastes		
2.3.3	Construction and Domestic Wastes		
2.3.4	Washing Applicators used for paint, stucco, concrete, etc.		
2.3.4	Washing Applicators used for paint, stucco, concrete, etc.		
2.3.4	Washing Applicators used for paint, stucco, concrete, etc.		
2.4	Dewatering		
2.1	Discharge off site?	• Yes • No	
4	Self-Inspection Reports	< 2 weeks	Latest Report Date:

Notes: (City Inspector Use) Items in compliance can be left blank.

¹ Construction General Permit (CGP)

Maintenance or corrective actions are to be completed within 7 days.

Notes:

temp sediment ponds will get graded later. site should drain to the middle until then

City of Albuquerque Stormwater Inspector Signature and Date:

Curtis A. Cherne

Signature

12-5-20

Date

Contact Info: Curtis Cherne, 505-924-3420, ccherne@cabq.gov