

CITY OF ALBUQUERQUE



December 30, 2011

Fred C. Arfman, P.E.
Isaacson & Arfman, P.A.
128 Monroe St. NE
Albuquerque, NM 87108

**Re: Cliff's Amusement Park, Water Play Structure, Grading and Drainage Plan
Engineer's Stamp date 12-14-11 (F17-D031A)**

Dear Mr. Arfman,

Based upon the information provided in your submittal received 12-14-11, the above referenced plan cannot be approved for Grading Permit until the following comments are addressed:

- Existing contours and spot elevations are not visible on the submitted plan.
- Please show the finished floor elevations for the existing structures.
- Provide hydraulic calculations for the proposed sidewalk culverts on the western edge of the property.

If you have any questions, you can contact me at 924-3695.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: file
CJH/SB