

CITY OF ALBUQUERQUE



December 27, 2017

David Soule, P.E.
Inspections Plus Inc.
4382 Alexander Blvd NE
Albuquerque, NM 87107

**Re: Floor and Decor
Erosion and Sediment Control Plan
Engineer's Stamp Date 10-17-17 (F17E032)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 10-17-17, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the condition:

1. It appears that grading is proposed to the back of curb on McLeod Rd. If this is the case, the silt fence will need to be installed at the back of curb.

PO Box 1293

Include a copy of the approved plan in the Building Permit set.

Albuquerque

The above referenced plan is also approved to be included in the Work Order Construction plans.

Include a copy of the approved plan in the Work Order construction plans.

NM 87103

If you have any questions, you can contact me at 924-3420.

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email