

CITY OF ALBUQUERQUE



February 6, 2018

David Soule, P.E.
Inspections Plus, Inc.
805 Nikanda NE
Albuquerque, NM 87107

**Re: Floor and Decor
Erosion and Sediment Control Plan
Engineer's Stamp Date 1-26-18 (F17E032)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 1-30-18, the above referenced plan is not approved to be included in the SWPPP or to be included in the Work Order construction plans until the following comments are addressed:

1. After discussion with the NMDOT, a sediment BMP should be proposed between the deceleration lane(s) and the swale on Pan American Frwy to prevent sediment from entering the swale area.
2. Please revise the note concerning self-inspections and include language for the required reports.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email