

CITY OF ALBUQUERQUE



October 12, 2018

David Soule, P.E.
Inspections Plus Inc.
805 Nikanda Rd NE
Albuquerque, NM 87107

**Re: TRU by Hilton Hotel
Erosion and Sediment Control Plan
Engineer's Stamp Date 10-4-18 (F17E044C)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 10-5-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the following condition:

1. The mulch sock sediment BMP is to be replaced with silt fence along the western edge and along the southern edge from the southwest corner of the project to the west side of the stabilized construction entrance.

PO Box 1293

This is due to proposed onsite grades being 4 to 7 feet higher than the adjacent grade.

Albuquerque

Please revise the plan and resubmit it electronically, only.

Include a copy of the approved plan in the Building Permit set.

NM 87103

If you have any questions, you can contact me at 924-3420.

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email