PUBLIC WORKS/HYDROLOGY

F17/D50

0000 0000 0975

F17/D50

25×10

0000 0000 0976

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

CLARENCE V. LITHGOW
CHIEF
ADMINISTRATIVE OFFICER

DAN WEAKS
DEPUTY CAO
PUBLIC SERVICES

FRED E. MONDRAGON
DEPUTY CAO
DEVELOPMENT & ENTERPRISE SERVICES

RAY R. BACA
DEPUTY CAO
PUBLIC SAFETY

July 18, 1989

Jeff Mortensen, P.E.
Jeff Mortensen & Associates, Inc.
811 Dallas, NE
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR INSTANT OIL ON SAN MATEO
(F-17/D50) ENGINEER'S STAMP DATED JULY 11, 1989

Dear Mr. Mortensen:

Based on the information provided on your submittal of July 12, 1989, the above referenced plan is approved for Building Permit and Foundation Permit release.

Please attach a copy of this plan to the construction sets prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj
(WP+370)

25×10

0000 0000 0977

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RETAIL CENTER AND CONVENIENCE STORE ZONE ATLAS/DRNG. FILE #: ~~F-12~~ F17 / D50

LEGAL DESCRIPTION: TRACTS "B" AND "C", LANDS OF NAVAJO TERMINALS, INC

CITY ADDRESS: _____

ENGINEERING FIRM: LOVELADY & ASSOCIATES CONTACT: FRANK LOVELADY

ADDRESS: 7408 MORROW AVE N.E. PHONE: 883-7973

OWNER: Mr. Calhoun CONTACT: _____

ADDRESS: _____ PHONE: 881-6482

ARCHITECT: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

RECEIVED OCT 28 1987 HYDROLOGY SECTION

PRE-DESIGN MEETING:

X YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED W/ORIGINAL SUBMITTAL

DRB NO. _____

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

___ REVISED DRAINAGE PLAN, Redesign of Grades on north end to minimize use of retaining walls.

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

___ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: October 28, 1987

BY: Frank D. Lovelady

25 x 10

0000 0000 0478

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RETAIL CENTER AND CONVENIENCE STORE ZONE ATLAS/DRNG. FILE #: ~~F-12~~ / F17/D50

LEGAL DESCRIPTION: TRACTS "B" AND "C", LANDS OF NAVAJO TERMINALS, INC.

CITY ADDRESS:

ENGINEERING FIRM: Lovelady & Associates CONTACT: Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE 87110 PHONE: 883-7973

OWNER: Mr. Calhoun CONTACT: Mr. Calhoun

ADDRESS PHONE: 881-6482

ARCHITECT: David W. Fry CONTACT: David W. Fry

ADDRESS: 2007 Ridgecrest PHONE: 255-8985

SURVEYOR: Lovelady & Associates CONTACT: Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE PHONE: 883-7973

CONTRACTOR: CONTACT:

ADDRESS: PHONE:

PRE-DESIGN MEETING:

X YES

___ NO

X COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED JAN 26 1988 HYDROLOGY SECTION

DRB NO.

EPC NO.

PROJECT NO.

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

X DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAIN. PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

OTHER _____ (SPECIFY)

DATE SUBMITTED: JANUARY 26, 1988

BY: Frank D. Lovelady
Frank D. Lovelady, P.E.

Rev. 11/84

25 x 10

0000 0000 0979

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

October 29, 1987

Frank Lovelady, P.E.
Lovelady & Associates
7408 Morrow Road, NE
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR RETAIL CENTER & CONVENIENCE STORE (F-17/D50) ENGINEER'S STAMP WITH REVISION DATE OF OCTOBER 28, 1987

Dear Mr. Lovelady:

Based on the information provided on your submittal of October 28, 1987, the above referenced plan is approved for Building Permit.

Please attach a copy of this plan to the construction sets prior to sign-off by Hydrology.

Also, please be advised that the building permit will not be issued until an approved copy of the replat or easement is submitted to our office for review.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

PUBLIC WORKS DEPARTMENT

Walter Nickerson, P.E., City Engineer

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER

25×10

0000 0000 0480

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT

ENGINEERING GROUP

FILE COPY

INTER-OFFICE CORRESPONDENCE October 30, 1987

TO:
Tom Aragon, Transportation System Division

FROM:
Fred J. Aguirre, Hydrologist; Engineering Group/PWD

SUBJECT:
PRIVATE DRAINAGE FACILITIES WITHIN PUBLIC RIGHTS-OF-WAY/EASEMENT
RETAIL CENTER & CONVENIENCE STORE (F-17/D50) SAN MATEO @ LINCOLN, NE

Transmitted herewith, is a copy of the approved drainage plan for the referenced project incorporating the S.O. #19 design.

In accordance with the new process, this plan is being submitted to you for permitting and inspection. Please provide this section with a signed-off copy per the signature block upon construction and acceptance by your office.

As you are aware, the signed-off S.O. #19 is required by this office for Certificate of Occupancy release; hence your expeditious processing of this plan would be greatly appreciated and would avoid any unnecessary delay in the release of the Certificate of Occupancy.

Thank you for your cooperation, and if you should have any questions and/or comments regarding the process, please feel free to call me at 768-2650.

FJA/bsj

Attachment

25×10

0000 0000 0981

DRAINAGE INFORMATION SHEET

PROJECT TITLE: INSTANT OIL SAN MATEO ZONE ATLAS/DRAINAGE FILE # F-17/D50

LEGAL DESCRIPTION: TRACTS B+C, LANDS OF NAVAJO TERMINALS

CITY ADDRESS: _____

ENGINEERING FIRM: JEFF MORTENSEN & ASSOC CONTACT: LEONARD UTTER

ADDRESS: 811 DALLAS N.E PHONE: 265-5611

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: HOLMES - SABATINI & EEDS CONTACT: DICK ENGSTROM

ADDRESS: 202 CENTRAL AVE. SE PHONE: 247-3705

SURVEYOR: JEFF MORTENSEN & ASSOC. CONTACT: LEONARD UTTER

ADDRESS: _____ PHONE: _____

CONTRACTOR: _____ CONTACT: ARCHITECT

ADDRESS: _____ PHONE: _____

PRE-DESIGN MEETING:

___ YES

✓ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED JUL 12 1989 HYDROLOGY SECTION

DRB NO. _____

EPC NO. _____

PROJECT NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

✓ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAIN PLAN

✓ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SECTOR PLAN APPROVAL

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

✓ BUILDING PERMIT APPROVAL

✓ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 07-12-89

BY: [signature]

25×10

0000 0000 0482

DRAINAGE INFORMATION SHEET

PROJECT TITLE: MUFFLER SHOP FOR CALHOUN ENTERPRISES, INC. ZONE ATLAS/DRNG. FILE #: F17/D50

LEGAL DESCRIPTION: TRACT "B-1" LANDS OF NAVAJO TERMINALS INC.

CITY ADDRESS: 4850 Lincoln Road

ENGINEERING FIRM: Lovelady & Associates CONTACT: Frank Lovelady

ADDRESS: 7408 Morrow Road, N.E. PHONE: 883 7973

OWNER: Calhoun Enterprises CONTACT: David Fry

ADDRESS: 112 Virginia, NE. PHONE: 299-5959

ARCHITECT: David Fry CONTACT: David Fry

ADDRESS: 2007 Ridgecrest Drive SE PHONE: 2558985

SURVEYOR: Douglas H. Smith CONTACT: Douglas H. Smith

ADDRESS: 300 San Mateo Blvd. NE PHONE: 266-9823

CONTRACTOR: N/A CONTACT: ____

ADDRESS: ____ PHONE: ____

PRE-DESIGN MEETING:

X YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED See Original Submittal

DRB NO. ____

EPC NO. ____

PROJ. NO. ____

RECEIVED FEB 15 1985 HYDROLOGY SECTION

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

X DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

X SECOND SUBMITTAL PER CARLOS A. MONTOYA'S LETTER OF FEB. 7, 1985

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER ____ (SPECIFY)

DATE SUBMITTED: February 15, 1985

BY: Frank D. Lovelady, P.E.

25×10

0000 0000 0983

I SIGNED PLAT + HAT reflects the proposed development lines. 2/8/85

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

February 7, 1985

Frank Lovelady
Lovelady & Associates
7408 Morrow Road, NE
Albuquerque, New Mexico 87110

RE: GRADING & DRAINAGE PLAN FOR MUFFLER SHOP FOR CALHOUN ENTERPRISES, INC. (F-17/D50) RECEIVED JANUARY 30, 1985

Dear Mr. Lovelady:

Based on the information provided on your January 30, 1985, listed are certain concerns that will need to be addressed before final approval is given:

1. New information sheet with resubmittal designation.
2. Engineer's stamp with signature and revision date.
3. Section showing swale for routing roof runoff on the west side of building.
4. Pond - 100 year water surface elevation designated on plan.
5. Emergency spillway location.
6. What is the elevation of the existing building to the east.
7. Please explain the two line designation just south of the proposed building.
8. Benchmarks - location, description and elevation of the:
   A. Temporary benchmark on-site.
9. Elevation of property line at least .33' above adjacent top of curb.

If you have any questions or comments regarding this project, please call me at 766-7644.

Cordially,

Carlos A. Montoya
City/County Floodplain Administrator

CAM:BJM/bsj

25×10

0000 0000 0484

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

MAYOR KEN SCHULTZ
CHIEF ADMINISTRATIVE OFFICER GENE ROMO
DEPUTY CAO PUBLIC SERVICES FRANK MARTINEZ
DEPUTY CAO PLANNING/DEVELOPMENT BILL MUELLER

February 5, 1988

Frank Lovelady, P.E.
Lovelady & Associates
7408 Morrow Road, NE
Albuquerque, New Mexico 87110

RE: REVISED DRAINAGE PLAN FOR RETAIL CENTER & CONVENIENCE STORE (F-17/D50) REVISION DATE OF JANUARY 26, 1988

Dear Mr. Lovelady:

Based on the information provided on your resubmittal dated January 26, 1988, the above referenced plan is approved for Building Permit.

Please attach a copy of this plan to the construction sets prior to sign-off by Hydrology. Also, please be advised that the building permit will not be issued until an approved copy of the replat or easement is submitted to our office for review.

Please advise your client that a separate permit is required for construction within City right-of-way.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

AN EQUAL OPPORTUNITY EMPLOYER

25×10

0000 0000 0485

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT

ENGINEERING GROUP

INTER-OFFICE CORRESPONDENCE

February 5, 1988

TO: Tom Aragon, Transportation System Division

FROM: Fred J. Aguirre, Hydrologist; Engineering Group/PWD

SUBJECT: PRIVATE DRAINAGE FACILITIES WITHIN PUBLIC RIGHTS-OF-WAY/EASEMENT
RETAIL CENTER & CONVENIENCE STORE (F-17/D50) SAN MATEO & LINCOLN, NE

Transmitted herewith, is a copy of the approved drainage plan for the referenced project incorporating the S.O. #19 design.

In accordance with the new process, this plan is being submitted to you for permitting and inspection. Please provide this section with a signed-off copy per the signature block upon construction and acceptance by your office.

As you are aware, the signed-off S.O. #19 is required by this office for Certificate of Occupancy release; hence your expeditious processing of this plan would be greatly appreciated and would avoid any unnecessary delay in the release of the Certificate of Occupancy.

Thank you for your cooperation, and if you should have any questions and/or comments regarding the process, please feel free to call me at 768-2650.

FJA/bsj

Attachment

25×10

0000 0000 0986

FILE COPY

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

September 10, 1987

Frank Lovelady, P.E.
Lovelady & Associates, Inc.
7408 Morrow Road, NE
Albuquerque, New Mexico 87110

RE: DRAINAGE PLAN FOR RETAIL CENTER & CONVENIENCE STORE
(F-17/D50) ENGINEER'S STAMP DATED SEPTEMBER 1, 1987

Dear Frank:

Based on the information provided on your submittal of September 3, 1987, the above referenced plan is approved for Building Permit.

Please be advised that the building permit will not be issued until an approved copy of the replat or easement is submitted to our office for review.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

25 x 10

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

February 15, 1985

Frank Lovelady
Lovelady & Associates
7408 Morrow Road, NE
Albuquerque, New Mexico 87110

RE: MUFFLER SHOP FOR CALHOUN ENTERPRISES, INC. (F-17/D50)
DRAINAGE PLAN RECEIVED FEBRUARY 15, 1985

Dear Mr. Lovelady:

The referenced plan dated February 13, 1985, is approved.

Please attach a copy of this approved plan to the construction set prior to Hydrology sign-off.

If I can be of further assistance, please call me at 766-7644.

Cordially,

Carlos A. Montoya
City/County Floodplain Administrator

CAM/bsj

25×10

0000 0000 0488

GRADING AND DRAINAGE PLAN

AND

SUPPLEMENTAL INFORMATION

FOR

RETAIL CENTER AND CONVENIENCE STORE

SAN MATEO BLVD. AND LINCOLN ROAD, N.E.

ZONE ATLAS NO. F-17 / D50

LOVELADY & ASSOCIATES

SEPTEMBER 1, 1987

25 x 10

0000 0000 0989

DRAINAGE INFORMATION SHEET

PROJECT TITLE: RETAIL CENTER AND CONVENIENCE STORE ZONE ATLAS/DRNG. FILE #: F-12 /

LEGAL DESCRIPTION: TRACTS "B" AND "C", LANDS OF NAVAJO TERMINALS, INC.

CITY ADDRESS:

ENGINEERING FIRM: Lovelady & Associates CONTACT: Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE 87110 PHONE: 883-7973

OWNER: Mr. Calhoun CONTACT: Mr. Calhoun

ADDRESS PHONE: 881-6482

ARCHITECT: David W. Fry CONTACT: David W. Fry

ADDRESS: 2007 Ridgecrest PHONE: 255-8985

SURVEYOR: Lovelady & Associates CONTACT: Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE PHONE: 883-7973

CONTRACTOR: CONTACT:

ADDRESS: PHONE:

PRE-DESIGN MEETING:

X YES

NO

X COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED SEP 03 1987 HYDROLOGY SECTION

DRB NO.

EPC NO.

PROJECT NO.

TYPE OF SUBMITTAL:

- DRAINAGE REPORT
- X DRAINAGE PLAN
- CONCEPTUAL GRADING & DRAIN. PLAN
- GRADING PLAN
- EROSION CONTROL PLAN
- ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

- SKETCH PLAT APPROVAL
- PRELIMINARY PLAT APPROVAL
- SITE DEVELOPMENT PLAN APPROVAL
- FINAL PLAT APPROVAL
- X BUILDING PERMIT APPROVAL
- FOUNDATION PERMIT APPROVAL
- CERTIFICATE OF OCCUPANCY APPROVAL
- ROUGH GRADING PERMIT APPROVAL
- GRADING/PAVING PERMIT APPROVAL
- OTHER (SPECIFY)

DATE SUBMITTED: SEPTEMBER 1, 1987

BY: Frank D. Lovelady
Frank D. Lovelady, P.E.

Rev. 11/84

25×10

0000 0000 0440

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: F17 DATE: 8/26/87 @ 10:30

PLANNING DIVISION NOS: EPC: _____ DRB: _____

SUBJECT: Shopping Ctr / Convenience Store

STREET ADDRESS (IF KNOWN): _____

SUBDIVISION NAME: Tract B & C Land of Navajo Freight

APPROVAL REQUESTED:

____	PRELIMINARY PLAT	____	FINAL PLAT
____	SITE DEVELOPMENT PLAN	X	BUILDING PERMIT
____	OTHER	____	ROUGH GRADING

	WHO	REPRESENTING
ATTENDANCE:	Frank Lovelady	Lovelady & Assoc.
	Bernie Montoya	Hydrology Section

FINDINGS:

1. Drainage Plan Per D.P.M requirements prior to Building Permit.

2. Flooding downstream on Lincoln Rd. If developed runoff will be routed toward Lincoln Rd. Then Engineer must address downstream capacity for free discharge.

3. Existing 60" R.C.P. on San Mateo with Drain Grates.

4. Engineer must address drainage across lot lines (replat or easements.)

5.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED:	Bernie J. Montoya	SIGNED:	Frank O. Lovelady
TITLE:	Engineering Assistant	TITLE:	
DATE:	8/26/87	DATE:	8/26/87

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL

25 × 10

0000 0000 0991

THE FOLLOWING DOCUMENT IS FILMED IN PARTS

25×10

0000 0000 0442



3 FOR
SECTION

25 x 10


MATCH LINE STA. 269+00 ℄ I-025
STRUCTURE # 12D-7
STA. 270+65.28, NBFR BL
BUILD CURB DROP INLET, TYPE I
TRANSITION FROM TYPE C CURB
TO TYPE B CURB AT INLET.
H= 3.75' (BDIC-003-04). BUILD
1-24" x 60' RCP (CLASS II) w/
CONC. BLANKET LT. @ STA. 1+15,
24' LT., RAMP JC BL. CONNECT TO
TO INLET STRUCTURE 12D-7
SKEW PIPE R.F. 6°.
STRUCTURE #12D-7
GRATE = 61.93
INV. = 57.65
STA. 270+93 40' LT. NBFR BL
REMOVE EXIST. 18" x 75' RCP
STRUCTURE # 12D-6
STA. 273+37, 34' LT., NB FR BL
BUILD 1-MEDIAN DROP INLET
(TYPE III, (MDI-1) H= 4.75'
CONNECT TO STRUCTURE 12D-9
w/ 1-30" x 48' RCP (CLASS II) &
BUILD 1-38" x 82' RCP (CLASS II)
w/ CONC. BLANKET LT. (BMS-033-02) @ STA.
RAMP JC BL. SKEW PIPE 87.55°
& CONNECT TO 12D-8.
STRUCTURE 12D-9
STA 273+25, 40' RT, NB FR BL =
0+40, 24' RT, LINCOLN RD ℄.
BUILD CURB INLETS TYPE III, TRANSITION
FROM TYPE C CURB TO TYPE B CURB
AT INLETS. H= 4.12' (BDIC-003-004
CONNECT TO STRUCTURE 12D-8 w/
1-30" x 69' RCP (CLASS II)
SKEW PIPE R.F. 72°
STRUCTURE 12D-10
STA 274+05, 80' RT., NB FR BL =
STA 0+77, 24' LT. LINCOLN RD ℄
BUILD CURB INLETS, TYPE III.
TRANSITION FROM TYPE C CURB TO
TYPE B CURB AT INLETS. H= 3.75' (BDIC-
003 & 004 ... CONNECT TO STRUCTURE
12D-9 w/ 1-84" x 68' RCP (CLASS II)
STA. 273+80, 98' LT, I-25 E RD.
STA. 276+20 20' RT, NBFR BL
EXIST. 36" RCP TO REMAIN
ALONG W/ EXIST. INLETS.
℄ LINCOLN RD.
RAMP JC
STRUCTURE #12D-8
TOP = 64.00
E INV = 59.75
S INV = 59.70
STRUCTURE #12D-3
RIM = 62.00
S INV = 55.19
INV = 55.74
E INV = 55.74 (EXIST)
STRUCTURE #12D-1
GRATE = 67.61
S INV = 61.70
N INV = 61.75
STRUCTURE #12D-2
GRADE TO INLET
EXIST. SIDEWALK
EXIST. SIDEWALK TO REMAIN
BUILD 1-18" x 24' RCP
BUILD 1-36" x 218' RCP
GRADE TO INLET
305' RCP @ 0.2295'/FT
EXISTING
REMOVE THIS PORTION OF EXIST. 36" x 60' RCP
STRUCTURE #12D-3
STA 274+00, 80' RT (S.B. FR BL)
BUILD 1-MANHOLE, TYPE III (MH-2)
H= 8.81' CONNECT TO EXIST. 36" RCP
STA. 274+58, 8' LT. BUILD JC
TO STA 274+00, 80' RT. SB FR
BL. REMOVE EXIST. 36" RCP
RCP.
STA 274+03, 80' RT. TO STA
72' RT (S.B. FR BL)
RCP CLASS II BETWEEN
EXISTING
STA 274+58 ℄ Med I-025 + Extn.
Exist. MDI-II 12"
270
275
3:1
25

0000 0000 0444

PLANS/PLATS ON FILE

FILE DESC: E17/D50

PLANS/PLATS 2

25 × 10

0000 0000 0995

25×10