HYDROLOGY

F17/D54

SIERRA VISTA

WAREHOUSE

FIN-D54

1 PLAN

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: F17 DATE: 11/20/85 @ 11:00

PLANNING DIVISION NOS: EPC: _____ DRB: _____

SUBJECT: Sierra Vista

STREET ADDRESS (IF KNOWN): _____

SUBDIVISION NAME: Midway Business Park; Lot 6-A

APPROVAL REQUESTED:

____	PRELIMINARY PLAT	____	FINAL PLAT
____	SITE DEVELOPMENT PLAN	X	BUILDING PERMIT
____	OTHER	____	ROUGH GRADING

	WHO	REPRESENTING
ATTENDANCE:	Parviz Etteghari	Hall Engineering
	Billy Goolsby	Design Hydrology

FINDINGS:

① Drainage Plan will required to comply with the Midway Business Park (E17/D41) Master Plan.

② An erosion control plan for the period of construction will be required to ensure that sediments remain onsite

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Billy J. Goolsby SIGNED: _____

TITLE: CE/Design Hydrology TITLE: _____

DATE: 11/20/85 DATE: _____

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL

DRAINAGE INFORMATION SHEET

Mi que of Singer & Office Blvd

PROJECT TITLE: SIERRA VISTA (WAREHOUSE) ZONE ATLAS/DRNG. FILE #: F-17-D54

LEGAL DESCRIPTION: LOT 6-A MIDWAY BUSINESS PARK

CITY ADDRESS: SINGER BLVD. NE

ENGINEERING FIRM: HALL ENGINEERING CONTACT: PARVIZ EFTEKHARI

ADDRESS: 337 EUBANK NE PHONE: 292-1115

OWNER: DON SANDOVAL CONTACT: DON SANDOVAL

ADDRESS: 2655 D PAN AM. FREEWAY 87107 PHONE: 345-3522

ARCHITECT: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

SURVEYOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

CONTRACTOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

PRE-DESIGN MEETING:

✓ YES

___ NO

✓ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. ___

EPC NO. ___

PROJ. NO. ___

RECEIVED NOV 21 1985 HYDROLOGY SECTION

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

✓ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

NO DRB
new file
NO EPC

DATE SUBMITTED: Nov. 21, 1985

BY: PARVIZ EFTEKHARI

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

December 9, 1985

Richard Hall
Hall Engineering
337 Eubank Blvd., NE
Albuquerque, New Mexico 87123

RE: DRAINAGE PLAN FOR SIERRA VISTA WAREHOUSE ON LOT 6-A OF MIDWAY BUSINESS PARK RECEIVED NOVEMBER 21, 1985 (F-17/D54)

Dear Mr. Hall:

The referenced plan dated November 21, 1985, is approved for building permit.

If you have any questions regarding this project, call me at 766-7644.

Cordially,

Carlos A. Montoya

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

BJM:CAM/bsj

DRAINAGE INFORMATION SHEET

PROJECT TITLE: SIERRA VISTA (WAREHOUSE) ZONE ATLAS/DRNG. FILE #: F-17/D54

LEGAL DESCRIPTION: LOT 6-A MIDWAY BUSINESS PARK

CITY ADDRESS: SINGER BLVD. NE

ENGINEERING FIRM: HALL ENGINEERING CONTACT: PARVIZ EFTEKHARI

ADDRESS: 337 EUBANK NE PHONE: 292-1115

OWNER: DON SANDOVAL CONTACT: DON SANDOVAL

ADDRESS: 2655 D PAN AM. FREEWAY 87107 PHONE: 345-3522

ARCHITECT: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

SURVEYOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

CONTRACTOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

RECEIVED JAN 15 1986 HYDROLOGY SECTION

PRE-DESIGN MEETING:

✓ YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. _____

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

✓ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: Jan. 15, 1986

BY: PARVIZ EFTEKHARI

x-tra

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

January 27, 1986

Richard Hall
Hall Engineering
337 Eubank Blvd., NE
Albuquerque, New Mexico 87123

RE: REVISED DRAINAGE PLAN FOR SIERRA VISTA WAREHOUSE
MIDWAY BUSINESS PARK; LOT 6-A - RECEIVED JANUARY 15, 1986
(F-17/D54)

Dear Mr. Hall:

I have reviewed the referenced drainage plan, and forward these comments, which will need to be addressed prior to final approval:

1. New information sheet with resubmittal designation.

2. Engineer's stamp with signature and revision date.

3. Please show the increase or decrease in building concrete, asphalt, and landscape areas and adjust your calculations to indicate the changes.

4. Please address how erosion will be controlled at the outlet of the 2" pvc line. It may be appropriate to route it through the curb using the Special Order 19 design document.

5. Please indicate the finish floor elevation to full mean sea level.

6. Also show all supporting calculations for the "Q" that will be released through the 2" pvc pipe.

7. Also, please investigate the adequacy of the building foundation for the ponding volume that will be impounded adjacent to the building in the event the sump pump does not function properly.

If you have any questions regarding this project, call me at 766-7644.

Cordially,

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

BJM:CAM/bsj

DRAINAGE INFORMATION SHEET

PROJECT TITLE: SIERRA VISTA (WAREHOUSE) ZONE ATLAS/DRNG. FILE #: F-17-D54

LEGAL DESCRIPTION: LOT 6-A MIDWAY BUSINESS PARK

CITY ADDRESS: SINGER BLVD. NE

ENGINEERING FIRM: HALL ENGINEERING CONTACT: PARVIZ EFTEKHARI

ADDRESS: 337 EUBANK NE PHONE: 292-1115

OWNER: DON SANDOVAL CONTACT: DON SANDOVAL

ADDRESS: 2655 D PAN AM. ~~FREEWAY~~ 87107 PHONE: 345-3522

ARCHITECT: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

SURVEYOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

CONTRACTOR: DURA BILT CONTACT: BILL SEGO

ADDRESS: 4808 JEFFERSON NE PHONE: 883-9100

RECEIVED JAN 29 1986 HYDROLOGY SECTION

PRE-DESIGN MEETING:

✓ YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. _____

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

✓ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: Jan. 29, 1986

BY: PARVIZ EFTEKHARI

HALL ENGINEERING COMPANY INC.
337 EUBANK N.E., SUITE 103
ALBUQUERQUE, NEW MEXICO 87123
Phones: (505) 292-1115 & 292-1116

Janury 29th, 1986

RECEIVED
JAN 29 1986
HYDROLOGY SECTION

Mr. Carlos A. Montoya
Design Hydrology Section
123 Central N.W.
Albuquerque, NM 87102

Dear Carlos

In responding to your comments regarding Sierra Vista Warehouse Drainage Plan (F17-D54), we would like to provide you some more information as follows:

Comment 3- Calculation has been revised

Comment 4- 2" PVC pipe is drainig on a cocrete pad as detail shows. There will be no errosion due to discharge.

Comment 6- See Plan

Comment 7- As per our conversation with Dura Bilt Product INc., building foundation at the vicinity of pond has 32" depth and will be sealed with two coat of Pitch up to elevation 26.00 against any water penetration.

If you have any questions or comments concerning this information please do not hesitate to call.

Sincerely

Parviz Ettekhari
Project Engineer

PE:jh

x-tra

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

February 5, 1986

Richard Hall
Hall Engineering
337 Eubank Blvd., NE
Albuquerque, New Mexico 87123

RE: REVISED DRAINAGE PLAN FOR SIERRA VISTA WAREHOUSE
MIDWAY BUSINESS PARK; LOT 6-A RECEIVED JANUARY 29, 1986
(F-17/D54)

Dear Mr. Hall:

The referenced plan, dated January 29, 1986, is approved for Building Permit sign-off.

If you have any questions regarding ths project, call me at 766-7644.

Cordially,

Carlos A. Montoya

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

BJM:CAM/bsj

PUBLIC WORKS/HYDROLOGY

F17/D54

0000 1003

F17/D54

25×10

0000 0000 1004

Address 3831 SINGER BLVD Engr/Arch FRANK LOVELADY
Plans Approved 11-9-89 ST 9-5-89 Cond.
Comments: F17/054 ADDITION to SIERRA VISTA OFFICE PRODUCTS

TEL 883 9100

Inspection Requested 2-7-90 Contractor DURA-BILT
Appr. 2-7-90 Disappr. 30 Day Temp.
Comments: FF El = TO EXISTING
NO CHG TO DRAINAGE, OVER EXIST IMP. AREA

25 × 10

0000 0000 1005

FILE COPY

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

September 29, 1989

Frank Lovelady
Lovelady & Associates
7408 Morrow, NE
Albuquerque, NM 87110

RE: DRAINAGE PLAN FOR AN ADDITION TO SIERRA VISTA OFFICE PRODUCTS (F-17/D54) ENGINEER'S STAMP DATED SEPTEMBER 5, 1989

Dear Mr. Lovelady:

Based on the information provided on your September 6, 1989 submittal, the above referenced drainage plan is approved for Building Permit.

Please attach a copy of this approved plan to the construction sites prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to contact us at 768-2650.

Sincerely,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM:jc
WP+1317

PUBLIC WORKS DEPARTMENT

Walter H. Nickerson, Jr., P.E.
Assistant Director Public Works

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER

25×10

0000 0000 1006

DRAINAGE INFORMATION SHEET

NEW BUILDING ADDITION FOR

PROJECT TITLE: SIERRA VISTA OFFICE PROD. **ZONE ATLAS/DRNG. FILE #:** F-17 / D-54

LEGAL DESCRIPTION: Lot 6-A, Midway Business Park

CITY ADDRESS: 3831 Singer Blvd. N.E.

ENGINEERING FIRM: Lovelady & Associates **CONTACT:** Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE 87110 **PHONE:** 883-7973

OWNER: Sierra Vista Office Porducts **CONTACT:** Jeff Foss

ADDRESS 4808 Jefferson, N.E. 87109 **PHONE:** 883-9100

ARCHITECT: Dura Bilt Products, Inc. **CONTACT:** Jeff Foss

ADDRESS: 4808 Jefferson, N.E. 87109 **PHONE:** 883-9100

SURVEYOR: Lovelady & Associates **CONTACT:** Frank Lovelady

ADDRESS: 7408 Morrow Ave. N.E. 87110 **PHONE:** 883-7973

CONTRACTOR: Dura-Bilt Products, Inc. **CONTACT:** Jeff Foss

ADDRESS: 4808 Jefferson N.E. 87109 **PHONE:** 883-9100

PRE-DESIGN MEETING:

RECEIVED SEP 06 1989 HYDROLOGY SECTION

X **YES** — **DRB NO.** _____

_____ **NO** — **EPC NO.** _____

X **COPY OF CONFERENCE RECAP SHEET PROVIDED** — **PROJECT NO.** _____

TYPE OF SUBMITTAL:

_____ **DRAINAGE REPORT**

X **DRAINAGE PLAN**

_____ **CONCEPTUAL GRADING & DRAIN. PLAN**

_____ **GRADING PLAN**

_____ **EROSION CONTROL PLAN**

_____ **ENGINEER'S CERTIFICATION**

CHECK TYPE OF APPROVAL SOUGHT:

_____ **SKETCH PLAT APPROVAL**

_____ **PRELIMINARY PLAT APPROVAL**

_____ **SITE DEVELOPMENT PLAN APPROVAL**

_____ **FINAL PLAT APPROVAL**

X **BUILDING PERMIT APPROVAL**

_____ **FOUNDATION PERMIT APPROVAL**

_____ **CERTIFICATE OF OCCUPANCY APPROVAL**

_____ **ROUGH GRADING PERMIT APPROVAL**

_____ **GRADING/PAVING PERMIT APPROVAL**

OTHER _____ **(SPECIFY)**

DATE SUBMITTED: September 5, 1989

BY: Frank D. Lovelady

Frank D. Lovelady, P.E.

Rev. 11/84 103

25×10

0000 0000 1007

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: F-17 DATE: 8/24/89 @ 10:00

PLANNING DIVISION NOS: EPC: _____ DRB: _____

SUBJECT: Sierra Vista

STREET ADDRESS (IF KNOWN): _____

SUBDIVISION NAME: Lot 6-A Midway Business Park

APPROVAL REQUESTED:

____	PRELIMINARY PLAT	____	FINAL PLAT
____	SITE DEVELOPMENT PLAN	X	BUILDING PERMIT
____	OTHER	____	ROUGH GRADING

RECEIVED SEP 04 1989 HYDROLOGY SECTION

	WHO	REPRESENTING
ATTENDANCE:	Frank Lovelady	Lovelady & Associates
	Bernie Montoya	Hydrology Section

FINDINGS:

1. Drainage plan per D.P.M. guidelines required prior to Building Permit release.
2. Free discharge permitted per the Master Drainage plan.
3. If area in question is pervious then update calculations must be included with the drainage plan.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED:	Bernie Montoya	SIGNED:	Frank D. Lovelady
TITLE:	Engineering Assistant	TITLE:	
DATE:	8/24/89	DATE:	8/24/89

YOU SHOULD RETAIN A COPY OF THIS REPORT WITH THE DRAINAGE SUBMITTAL

25 × 10

0000 0000 1008

PLANS/PLATS ON FILE

FILE DESC: F17/D54

PLANS/PLATS 1

25×10

0000 0000 1009

25×10

PUBLIC WORKS/HYDROLOGY

F17/D54

0000 0000 1003

F17/D54

25×10

0000 0000 1004

Address 3831 SINGER BLVD Engr/Arch FRANK LOVELADY
Plans Approved 11-9-89 ST 9-5-89 Cond.
Comments: F17/D54 ADDITION TO SIERRA VISTA OFFICE PRODUCTS

TEL 883 9100

Inspection Requested 2-7-90 Contractor DURA-BILT
Appr. 2-7-90 Disappr. 30 Day Temp.
Comments: FF EL = TO EXISTING
NO CHG TO DRAINAGE, OVER EXIST IMP. AREA

25×10

0000 0000 1005

FILE COPY

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

ALBUQUERQUE NEW MEXICO 1706

KEN SCHULTZ
MAYOR

September 29, 1989

Frank Lovelady
Lovelady & Associates
7408 Morrow, NE
Albuquerque, NM 87110

RE: DRAINAGE PLAN FOR AN ADDITION TO SIERRA VISTA OFFICE PRODUCTS (F-17/D54) ENGINEER'S STAMP DATED SEPTEMBER 5, 1989

Dear Mr. Lovelady:

Based on the information provided on your September 6, 1989 submittal, the above referenced drainage plan is approved for Building Permit.

Please attach a copy of this approved plan to the construction sites prior to sign-off by Hydrology.

If I can be of further assistance, please feel free to contact us at 768-2650.

Sincerely,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM:jc
WP+1317

PUBLIC WORKS DEPARTMENT

Walter H. Nickerson, Jr., P.E.
Assistant Director Public Works

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER

25 × 10

0000 0000 1006

DRAINAGE INFORMATION SHEET

NEW BUILDING ADDITION FOR

PROJECT TITLE: SIERRA VISTA OFFICE PROD. **ZONE ATLAS/DRNG. FILE #:** F-17 / D-S1

LEGAL DESCRIPTION: Lot 6-A, Midway Business Park

CITY ADDRESS: 3831 Singer Blvd. N.E.

ENGINEERING FIRM: Lovelady & Associates **CONTACT:** Frank Lovelady

ADDRESS: 7408 Morrow Ave. NE 87110 **PHONE:** 883-7973

OWNER: Sierra Vista Office Porducts **CONTACT:** Jeff Foss

ADDRESS 4808 Jefferson, N.E. 87109 **PHONE:** 883-9100

ARCHITECT: Dura Bilt Products, Inc. **CONTACT:** Jeff Foss

ADDRESS: 4808 Jefferson, N.E. 87109 **PHONE:** 883-9100

SURVEYOR: Lovelady & Associates **CONTACT:** Frank Lovelady

ADDRESS: 7408 Morrow Ave. N.E. 87110 **PHONE:** 883-7973

CONTRACTOR: Dura-Bilt Products, Inc. **CONTACT:** Jeff Foss

ADDRESS: 4808 Jefferson N.E. 87109 **PHONE:** 883-9100

PRE-DESIGN MEETING:

X YES

____ NO

X COPY OF CONFERENCE RECAP SHEET PROVIDED

RECEIVED SEP 06 1989 HYDROLOGY SECTION

DRB NO. _____

EPC NO. _____

PROJECT NO. _____

TYPE OF SUBMITTAL:

____ DRAINAGE REPORT

X DRAINAGE PLAN

____ CONCEPTUAL GRADING & DRAIN. PLAN

____ GRADING PLAN

____ EROSION CONTROL PLAN

____ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

____ SKETCH PLAT APPROVAL

____ PRELIMINARY PLAT APPROVAL

____ SITE DEVELOPMENT PLAN APPROVAL

____ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

____ FOUNDATION PERMIT APPROVAL

____ CERTIFICATE OF OCCUPANCY APPROVAL

____ ROUGH GRADING PERMIT APPROVAL

____ GRADING/PAVING PERMIT APPROVAL

OTHER _____ (SPECIFY)

DATE SUBMITTED: September 5, 1989

BY: Frank D. Lovelady

Frank D. Lovelady, P.E.

Rev. 11/84

103

25 × 10

0000 0000 1007

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: F-17 DATE: 8/24/89 @ 10:00

PLANNING DIVISION NOS: EPC: _____ DRB: _____

SUBJECT: Sierra Vista

STREET ADDRESS (IF KNOWN): _____

SUBDIVISION NAME: Lot 6-A Midway Business Park

APPROVAL REQUESTED:

____	PRELIMINARY PLAT	____	FINAL PLAT
____	SITE DEVELOPMENT PLAN	X	BUILDING PERMIT
____	OTHER	____	ROUGH GRADING

RECEIVED SEP 04 1989 HYDROLOGY SECTION

	WHO	REPRESENTING
ATTENDANCE:	Frank Lovelady	Lovelady & Associates
	Bernie Montoya	Hydrology Section

FINDINGS:

1. Drainage plan per D.P.M. guidelines required prior to Building Permit release.
2. Free discharge permitted per the master Drainage plan.
3. If area in question is pervious then update calculations must be included with the drainage plan.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED:	Bernie Montoya	SIGNED:	Frank D. Lovelady
TITLE:	Engineering Assistant	TITLE:	
DATE:	8/24/89	DATE:	8/24/89

25×10

0000 0000 1008

PLANS/PLATS ON FILE

FILE DESC: F17/D54

PLANS/PLATS 1

25×10

0000 0000 1009

25×10