HYDROLOGY F17/D57 FOUR PLANS

F17/D57

4 Plans

URS
AN INTERNATIONAL PROFESSIONAL SERVICES ORGANIZATION

URS CORPORATION
5700 HARPER DRIVE NORTHEAST, SUITE 470
ALBUQUERQUE, NEW MEXICO 87109
TEL: (505) 822-1484

ALBUQUERQUE
ANCHORAGE
CLEVELAND
COLORADO SPRINGS
DALLAS
DENVER
JUNEAU
MINNEAPOLIS
NEW YORK
SAN FRANCISCO
SAN MATEO
SANTA FE
SEATTLE
TUCSON
TACOMA
WASHINGTON D.C.

F17-057

October 2, 1987

RECEIVED
OCT 02 1987
HYDROLOGY SECTION

Mr. Frank Schultz
G.W. Walker & Co.
150 Louisiana Blvd. NE.
Albuquerque, NM 87108

RE: Goodmans Interiors

Dear Frank:

Per your request, we have verified the first level finished floor elevation for subject project.

Field investigations indicate the finished floor elevation to be 5123.08.

If you have any questions, please call.

Very truly yours,

Gary W. Tibljas P.E.
Albuquerque Operations Manager

GWT:dd

F17-D57

Goodmans

NEW MEXICO STATE HIGHWAY
AND TRANSPORTATION DEPARTMENT
AN EQUAL OPPORTUNITY EMPLOYER

GARREY CARRUTHERS
GOVERNOR

COMMISSION

Willie Ortiz
Chairman, Santa Fe

J. V. "Rip" Curtis
Vice-Chairman, Clovis

Emerlinda De Brine
Secretary, Socorro

Jack Westman
Member, Albuquerque

Dr. Donald Reif
Member, Clayton

Mary Jean Smith-Christensen
Member, Gallup

DEPARTMENT

Secretary
Dewey Lonsberry

General Office
P.O. Box 1149
Santa Fe, N.M.
87504-1149
505-827-5100

District One Office
P.O. Box 231
Deming, N.M.
88031-0231
505-546-2603

District Two Office
P.O. Box 1457
Roswell, N.M.
88202-1457
505-624-3300

District Three Office
P.O. Box 3768
Station D
Albuquerque, N.M.
87190-3768
505-841-2700

District Four Office
P.O. Box 30
Las Vegas, N.M.
87701-0030
505-425-7527

District Five Office
P.O. Box 4127
Coronado Station
Santa Fe, N.M.
87502-4127
505-827-8500

District Six Office
P.O. Box G
Milan, N.M.
87021
505-285-6623

September 29, 1987

Hydrology Department
City of Albuquerque
Utility Development Division
P. O. Box 1293
Albuquerque, New Mexico 87103

ATTENTION: Bernie Montoya

RE: I-IR-025-4(65)223
I-025-4(71)223

Please be advised that driveway and drainage features constructed in New Mexico State Highway Department right-of-way at 4860 Pan American East are acceptable as constructed.

Thank-you.

Barbara Bovee'

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

July 16, 1987

Douglas W. Copeland, P.E.
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114

RE: REVISED DRAINAGE PLAN (SHEET 2 OF 3 ONLY) FOR GOODMAN'S, INC.
(F-17/D57) REVISION DATE OF JULY 7, 1897

Dear Doug:

Based on the information provided on your resubmittal of July 7, 1987, revisions as indicated are acceptable. The Building Permit has already been released, therefore, please provide the contractor with a copy of this approved plan.

Also, please be advised that prior to Certificate of Occupancy release, finish floor certification and State Highway acceptance must be submitted to our office.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

PUBLIC WORKS DEPARTMENT

Walter Nickerson, P.E., City Engineer

ENGINEERING GROUP

Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER

LETTER OF TRANSMITTAL

EASTERLING & ASSOCIATES, INC.
5643 Paradise Blvd. NW
ALBUQUERQUE, NEW MEXICO 87114

(505) 898-8021

DATE 7/7/87 JOB NO. 705205

ATTENTION BARBARA -

RE: GOODMANS GRADING DRAINAGE PLAN

TO CITY OF ALBQ. HYDROLOGY

WE ARE SENDING YOU ☐ Attached ☐ Under separate cover via _____ the following items:

☐ Shop drawings ☐ Prints ☐ Plans ☐ Samples ☐ Specifications

☐ Copy of letter ☐ Change order ☐ _____

COPIES	DATE	NO.	DESCRIPTION
1	7/7/87		DRAINAGE INFO SHEET
2	7/7/87		SHEET 2 OF GRADING PLAN

RECEIVED JUL 07 1987 HYDROLOGY SECTION

THESE ARE TRANSMITTED as checked below:

☐ For approval ☐ Approved as submitted ☐ Resubmit ____ copies for approval

☐ For your use ☐ Approved as noted ☐ Submit ____ copies for distribution

☐ As requested ☐ Returned for corrections ☐ Return ____ corrected prints

☐ For review and comment ☐ _____

☐ FOR BIDS DUE _____ 19____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS BARBARA - THIS PROJECT HAS BEEN APPROVED PREVIOUSLY. THIS SUBMITTAL IS A SITE PLAN CHANGE. PLEASE HAVE IT REVIEWED AND INSERTED IN PLACE OF THE PREVIOUSLY APPROVED SHEET 2 OF 5.

COPY TO Bernie J Montoya SIGNED: DOUGLAS

If enclosures are not as noted, kindly notify us at once.

PRODUCT 240-2 NEBS Inc. Groton, Mass. 01471

DRAINAGE INFORMATION SHEET

PROJECT TITLE: Goodman's, Inc. ZONE ATLAS/DRNG. FILE #: F17/D57

LEGAL DESCRIPTION: Lot A-1-A (Easterly portion) Cora Jett Tract, Tract 5-A-1, Reindeer Addition

CITY ADDRESS: I-25 Frontage Road, North Bogan Street, Albuquerque, New Mexico

ENGINEERING FIRM: Easterling & Associates, Inc. CONTACT: Douglas W. Copeland

ADDRESS: 5643 Paradise Blvd., NW, Alb., NM 87114 PHONE: 898-8021

OWNER: Goodman's inc. CONTACT:

ADDRESS: 2701 PanAmerican Fwy NE PHONE: 345-1621

ARCHITECT: G.W. Walker & Company CONTACT: Robert Becker

ADDRESS: 150 Louisiana Blvd., NE, Alb., NM 87108 PHONE: 268-4551

SURVEYOR: Southwest Surveying Company, Inc. CONTACT: Franklin Wilson

ADDRESS: 333 Lomas Blvd., NE, Alb., NM 87102 PHONE: 247-4444

CONTRACTOR: SUNDANCE MECHANICAL CONTACT:

ADDRESS: PHONE:

RECEIVED JUL 07 1987 HYDROLOGY SECTION

PRE-DESIGN MEETING:

___ YES

___ NO

X COPY OF CONFERENCE RECAP SHEET PROVIDED

See Sheet 1 of 2 of original submittal in your file.

DRB NO. ___

EPC NO. ___

PROJ. NO. ___

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

X GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER ___ (SPECIFY)

Resubmitted - 7/7/87

Re: 3/31/87 Sheet 2 of 3 only

DATE SUBMITTED:

BY: Douglas W. Copeland

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

April 8, 1987

Douglas W. Copeland
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114

RE: REVISED DRAINGAE PLAN FOR GOODMAN'S INC.
(F-17/D57) ENGINEERS STAMP DATED MARCH 31, 1987

Dear Doug:

First off, I would like to apologize to you for causing you to take exception to my previous review. I have a very high respect for your professional attitude and ethics as a fellow engineer and as a person.

As you are aware, I have a sense of pride in doing my job as a public servant and view my position as trying to achieve the best product. I have to regard any and all development with the same respect for purpose of protecting, to the best of my ability, the general public against potential problems and or liabilities resulting from development. In closing, I would like to commend you for taking the attitude that all problems can be satisfied in a gentleman type manner. I look forward to working with you on future submittals.

Based on the information provided on your resubmittal of April 2, 1987, the above referenced drainage plan is approved for Building Permit.

Please attach a copy of this approved plan to the construction sets prior to Hydrology sign-off. Also, before the Certificate of Occupancy can be released, finish floor certification and State Highway acceptance must be submitted to our office.

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

PUBLIC WORKS DEPARTMENT
Walter Nickerson, P.E., City Engineer
ENGINEERING GROUP
Telephone (505) 768-2500

AN EQUAL OPPORTUNITY EMPLOYER

- Mailed -

LETTE . OF TRANSMITTAL

EASTERLING & ASSOCIATES, INC.
5643 Paradise Blvd. NW
ALBUQUERQUE, NEW MEXICO 87114

(505) 898-8021

TO CITY HYDROLOGY

DATE 4/6/87 JOB NO. 705201
ATTENTION BERNIE MONTOYA
RE: GOODMAN'S G.D

WE ARE SENDING YOU ☐ Attached ☐ Under separate cover via _____ the following items:

☐ Shop drawings ☐ Prints ☐ Plans ☐ Samples ☐ Specifications
☐ Copy of letter ☐ Change order ☐ _____

COPIES	DATE	NO.	DESCRIPTION
1	4/1/87	1	CONFERMEMO FROM NMSHD - BARBARA Bovee

RECEIVED
APR 08 1987
HYDROLOGY SECTION

THESE ARE TRANSMITTED as checked below:

☐ For approval ☐ Approved as submitted ☐ Resubmit _____ copies for approval
☑ For your use ☐ Approved as noted ☐ Submit _____ copies for distribution
☑ As requested ☐ Returned for corrections ☐ Return _____ corrected prints
☐ For review and comment ☐ _____
☐ FOR BIDS DUE _____ 19 _____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS BERNIE - THIS CONFERMEMO IN ADDITION TO OUR RESUBMITTAL OF THE REVISED GRADING & DRAINAGE PLAN SHOULD SATISFY YOUR CONCERNS SUFFICIENTLY TO ~~ISSUE~~ APPROVE G.D PLAN FOR BUILDING PERMIT. PLEASE LET ME KNOW IF THERE IS ANYTHING ELSE. PLEASE CARBON COPY THE DEVELOPER WITH APPROVAL LETTER.

COPY TO Hal Walker file

SIGNED: DOUGLAS W. [illegible]

Imagetek Corporation CARROLLTON TEXAS 75006

RECEIVED
APR 08 1987
HYDROLOGY SECTION

NEW MEXICO STATE HIGHWAY DEPARTMENT

FORM A-267

CONFERMEMO

RECEIVED APR 06 1987

TO DOUG W COPELAND DATE 4/1/87

EASTERLING AND ASSOC.

5643 PARADISE BLVD CITY 87114

I HAVE REVIEWED YOUR SITE PLAN FOR Goodman's Inc AND FIND THE DRAINAGE PLANS ACCEPTABLE, SPECIFICALLY THE CONCRETE RUN DOWN ALONG THE WESTERN PROPERTY LINE

SIGNED

PLEASE REPLY HERE

TO DATE

AND INSTALLATION OF 2-30" x 44" CMPS AT DRIVEWAY.

PLEASE HAVE YOUR CONTRACTOR CONTACT THIS OFFICE PRIOR TO SETTING PIPES AT THE TURNOUT AS NEW DITCH ELEVATIONS MAY BE CUT.

SIGNED BARBARA BOVEE

NOTE: INDIVIDUAL ORIGINATING CONFERMEMO RETAINS YELLOW COPY. FORWARDING FIRST AND TRIPLICATE INTACT WITH CARBONS. ADDRESSEE REPLIES, EXTRACTS CARBON RETAINS TRIPLICATE, RETURNING FIRST PART TO ORIGINATOR OF CONFERMEMO.

LETTER OF TRANSMITTAL

EASTERLING & ASSOCIATES, INC.
5643 Paradise Blvd. NW
ALBUQUERQUE, NEW MEXICO 87114

(505) 898-8021

TO City Hydrology

DATE 4/2/87	JOB NO. 705201
ATTENTION Bernie Montoya	
RE: Goodman's S.D.	
Resubmit	

WE ARE SENDING YOU ☐ Attached ☐ Under separate cover via _____ the following items:

☐ Shop drawings ☐ Prints ☐ Plans ☐ Samples ☐ Specifications

☐ Copy of letter ☐ Change order ☐ _____

COPIES	DATE	NO.	DESCRIPTION
2	3/31/87	1,2,3	Goodman's S.D.

RECEIVED
APR 02 1987
HYDROLOGY SECTION

THESE ARE TRANSMITTED as checked below:

☐ For approval ☐ Approved as submitted ☐ Resubmit _____ copies for approval

☐ For your use ☐ Approved as noted ☐ Submit _____ copies for distribution

☐ As requested ☐ Returned for corrections ☐ Return _____ corrected prints

☐ For review and comment ☐ _____

☐ FOR BIDS DUE _____ 19 _____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS _____

COPY TO B Montoya

SIGNED: Douglas A

If enclosures are not as noted, kindly notify us at once.

PRODUCT 240-2 NEBS Inc., Groton, Mass. 01471

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

March 24, 1987

Douglas W. Copeland
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114

RE: DRAINGAE PLAN FOR GOODMAN'S INC.
(F-17/D57) RECEIVED FEBRUARY 12, 1987

Dear Doug:

Based on the information provided on your submittals of February 12, and March 16, 1987, listed you will find certain items that will need to be addressed prior to building permit approval.

1. Pond (Area 2) 100 year water surface elevation outlined and indicated on plan (D.P.M. 22.7-7).

2. Note identifying that certification of finish floor elevation must be done by Engineer upon completion of proposed construction. (Flood Hazard Ordinance 7-3-6-3.)

3. Hydraulic characteristics of proposed sump pump.

4. Will the 6" proposed median curb on the southeast property line block the 1.92 cfs off-site flows or will it be flush with the top of ground slope?

5. Application to the Highway Department indicated only for the 30" corrugated metal pipes. Do they concur with the overall scheme of the proposed development to release developed runoff into their right-of-way via a rock and gravel swale?

6. Final plans should not include "(preliminary subject to review)".

7. Bench Marks - Location, description, and elevation of the:

   A. Albuquerque Control Survey Vertical Datum.
   B. Temporary Benchmark on site (D.P.M. General Information 4-A,B).

If I can be of further assistance, please feel free to call me at 768-2650.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

Easterling & Associates, Inc.

5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114
(505) 898-8021

RECEIVED
MAR 16 1987
HYDROLOGY SECTION

March 12, 1987

Mr. Carlos A. Montoya, P.E.
City/County Floodplain Administrator
Utility Development Division
Hydrology Section
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87103

RE: DRAINAGE PLAN FOR GOODMAN'S, INC. (F-17/D57)

Dear Mr. Montoya:

In accordance with your letter, dated March 10, 1987, a copy of the approved Application for Permit to Construct Driveway on Public Right-of-Way under jurisdiction of State Highway Department is enclosed for your review. I trust this will satisfy your concerns sufficiently to release the building permit for the subject property.

If you should have any questions, please do not hesitate to contact me.

Sincerely,

Douglas W. Copeland, P.E.
Project Engineer

DWC:ch
Job No. 705201

Enclosure

xc: Mr. Robert Becker, AIA

Form M-201
Revised 8-2-68

RECEIVED MAR 09 1987

STATE HIGHWAY DEPARTMENT OF NEW MEXICO

SANTA FE, NEW MEXICO

Orig.-G.O. Files (White)
1 copy-District Engineer (Blue)
1 copy-Applicant (White)
1 copy-Traffic Services Engr. (Pink)

District No. 3
State Hwy. No. I-25
Project No. I-IR-025-4(65)223
Permit No. 3-1808

J-IR-025-4(65) 223

APPLICATION FOR PERMIT TO CONSTRUCT DRIVEWAY ON PUBLIC RIGHT-OF WAY

RECEIVED MAR 16 1987 HYDROLOGY SECTION

To: STATE HIGHWAY DEPARTMENT OF NEW MEXICO
Attn: DISTRICT HIGHWAY ENGINEER

Albuquerque, NEW MEXICO

APPLICATION is hereby made by MURRAY E. & DOROTHY J. GOODMAN (Name of Applicant) (Full Office Address)

For permission to construct driveway(s) at the following described location: East Frontage Road, I-25 between Bogan Avenue and McLeod Road. Albuquerque Zone Atlas Map No. F-17.

in Bernalillo County, along State Highway No. I-25 in accordance with attached plan or sketch. Work will commence on or about June, 1987 and will require approximately 14 days.

~~Gate (-), Cattleguard (-), Additional Fence (-),~~ TW2(2) 30 Inch Corrugated metal pipes will be required which applicant agrees to furnish and hereafter maintain in good repair ~~and closed to livestock.~~ the flow in the drainage ditch adjacent to Frontage Road has been calculated to be 63 CFS for a 100-year storm

If this permit is granted, we further agree to comply with all the conditions, restrictions and regulations of the State Highway Department.

Murray Goodman
(Owner)

By Murray E. Goodman
Title Pres - Goodmans Inc

my comm exp 4-18-89

PERMIT granted this 4th day of March 1987

Subject to the above stated conditions and the following additional requirements:

NOTE: Due to ongoing construction projects at this location, this permit is contingent to the plans of the contractor and must be coordinated with Project Manager Barbara Bovee, 2419 Carlisle, N.E. Alb. N.M. phone 841-6504.

All work performed on State Right-of-Way must meet the Standard Specifications for Road and Bridge Construction (Edition of 1984).

Traffic Control shall be in accordance with Manual on Uniform Traffic Control Devices for Streets and Highways.

The State Right-of-Way must be restored to its original condition or better.

STATE HIGHWAY DEPARTMENT OF NEW MEXICO

By
District Highway Engineer

copy sent to Bob Becker, G.W. Walker 3-9-87

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

Ken Schultz
Mayor

UTILITY DEVELOPMENT DIVISION
HYDROLOGY SECTION
(505) 768-2650

March 10, 1987

Douglas W. Copeland, P.E.
Easterling & Associates, Inc.
5643 Paradise Boulevard, NW
Albuquerque, New Mexico 87114

RE: DRAINAGE PLAN FOR GOODMAN'S, INC.
(F-17/D57) RECEIVED FEBRUARY 12, 1987

Dear Mr. Copeland:

The above referenced plan dated February 11, 1987, is approved for "Foundation Only".

Prior to release of the Building Permit, please submit concurrence from the State Highway Department for work in their right-of-way.

If you have any questions, call me at 768-2650.

Cordially,

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

CAM/bsj

LETTER OF TRANSMITTAL

EASTERLING & ASSOCIATES, INC.
5643 Paradise Blvd. NW
ALBUQUERQUE, NEW MEXICO 87114

(505) 898-8021

DATE 2/11/87	JOB NO. 705201
ATTENTION CARLOS MONTOYA	
RE: GOODMAN'S GRADING & DRAINAGE PLAN	

TO CITY HYDROLOGY SECTION

WE ARE SENDING YOU ☐ Attached ☐ Under separate cover via _____ the following items:

☐ Shop drawings ☒ Prints ☐ Plans ☐ Samples ☐ Specifications
☐ Copy of letter ☐ Change order ☐ _____

COPIES	DATE	NO.	DESCRIPTION
2	2/11/87	1-3	GRADING & DRAINAGE PLAN

RECEIVED
FEB 12 1987
HYDROLOGY SECTION

THESE ARE TRANSMITTED as checked below:

☒ For approval ☐ Approved as submitted ☐ Resubmit ____ copies for approval
☐ For your use ☐ Approved as noted ☐ Submit ____ copies for distribution
☐ As requested ☐ Returned for corrections ☐ Return ____ corrected prints
☐ For review and comment ☐ _____
☐ FOR BIDS DUE _____ 19____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS CARLOS - PLEASE REVIEW & COMMENT. YOUR APPROVAL WILL BE HELD IN HIGH REGARD. WHEN FACKS FROM WATER & SEWER REVIEW, THEY SHOULD BE AWARE THAT FIRE LINES TO PROPOSED FIRE HYDRANTS CANNOT BE SHOWN UNTIL A WATER & SEWER AVAILABILITY STATEMENT HAS BEEN RECEIVED. REQUEST WAS MADE 4 WEEKS AGO.

COPY TO Barbara Jaramillo 2/12

SIGNED: Douglas L. Cope

If enclosures are not as noted, kindly notify us at once.

PRODUCT 240-2 NEBS Inc., Groton, Mass. 01471

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: F17 DATE: 1-14-87

PLANNING DIVISION NOS: EPC: _____ DRB: _____

SUBJECT: Goodman Inc Design Interiors

STREET ADDRESS (IF KNOWN): _____

SUBDIVISION NAME: at frontage Rd and Bogan

APPROVAL REQUESTED:

____ PRELIMINARY PLAT	____ FINAL PLAT
____ SITE DEVELOPMENT PLAN	X BUILDING PERMIT
____ OTHER	____ ROUGH GRADING

ATTENDANCE:	WHO	REPRESENTING
	Dave Copeland	
	Carlos A Martyr	

FINDINGS:

(1) Drainage plan per DPM
(2) Need to coordinate work on state property with Highway Dept
(3) Culverts under access road need to be sized for 100 year storm
(4) Need to address drainage on frontage rd shoulder to determine depth of flow (elevation of 100 year storm) Finish floor needs to be 1 foot above water surface
(5) Free discharge appears appropriate engineer need to address
(A) site at bottom of watershed
(B) infill site
(C) other properties are free discharge
(D) minimum impact on downstream drainage facilities

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Carlos Martyr	SIGNED: [illegible]
TITLE:	TITLE:
DATE: 1-14-87	DATE: [illegible]

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL