

CITY OF ALBUQUERQUE



October 25, 2012

Mike Balaskovtis, P.E.
Bohannon Huston, Inc.
7500 Jefferson St. NE Courtyard 1
Albuquerque, NM 87109

**Re: Liberty Dialysis - Albuquerque
Grading and Drainage Plan
Engineer's Stamp date 10-9-12 (F17-D061J)**

Dear Mr. Balaskovits,

Based upon the information provided in your submittal received 10-09-12, the above referenced plan is approved for Paving Permit. Hydrology is requesting that proposed landscape areas be depressed to retain/infiltrate the rain that falls on them.

Albuquerque's MS4 Permit became effective March 1st, 2012. Grading and Drainage Plans and Drainage Reports will have to comply with the requirements of the new permit. The permit is available online at <http://www.cabq.gov/planning/landcoord/documents/EPA-NMS000101-FinalPermit.pdf>

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

If one acre or more is being disturbed this project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge.

If $\frac{3}{4}$ acre or more is being disturbed Topsoil Disturbance Permit will be required.

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

If you have any questions, you can contact me at 924-3695 or Rudy Rael at 924-3977.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

RR/SB
C: Email