

CITY OF ALBUQUERQUE



March 26, 2012

David Soule, P.E.
Rio Grande Engineering
P.O. Box 93924
Albuquerque, NM 87199

Re: Hampton @25 Grading and Drainage Plan
Engineer's Stamp date 03-19-12 (F-17/D088)


Dear Mr. Soule,

Based upon the information provided in your submittal received 03-21-12, the above referenced plan cannot be approved for Building and Grading Permit until the following comments are addressed:

- Indicate the direction of roof flows on the plan.
- Provide details of cobble swale on the southern portion of the site.
- Water block symbol should be added to the legend as well as what appears to be a headwall on the southwest portion of the lot.
- Correct p.3 of the drainage report to indicate that the site drains from northeast to southwest.
- Please show basin boundaries on grading plan.

If you have any questions, you can contact me at 924-3695.

Sincerely,



Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: File
CJH\SB

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov