

CITY OF ALBUQUERQUE



**Planning Department
Transportation Development Services Section**

April 9, 2014

David Soule P.E.
Rio Grande Engineering
P.O. Box 93924
Albuquerque, NM 87199

**Re: Albuquerque Heights Seventh Day Adventist Church,
4920 Wyoming Blvd NE
Certification Submittal for Certificate of Occupancy – Transportation
Development
Engineer's Stamp dated 6-22-13 (F20-D021)
Certification dated 4-07-14**

Dear Mr. Soule,

The Letter of Certification submitted on 04-07-14 is not sufficient for acceptance by this office for final Certificate of Occupancy (C.O.). The following items need to be addressed:

- The grade change at the pedestrian walkway from the right-of-way on Wyoming Blvd exceeds the maximum slope allowed. We suggest adding a landing to the pedestrian walkway to meet the minimum slope allowed.

Resubmit acceptable package along with fully completed Drainage Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation.

Sincerely,

Racquel M. Michel, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: File
CO Clerk