

CITY OF ALBUQUERQUE



June 26, 2015

David Soule, P.E.
Rio Grande Engineering
9171 Glendale Ave NE
Albuquerque, NM 87122

**Re: Sandia Area Federal Credit Union
Erosion Sediment Control Plan
Engineer's Stamp Date 6-22-15 (F22E002)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 6-23-15 the above referenced plan is approved to be included in the SWPPP and for Grading Permit/Building Permit once the grading plan is approved by Hydrology with the following conditions:

1. Include a waddle at the base of the silt fence in the existing entrance onto Montgomery Blvd and the access on the west side.
2. Provide inlet protection for the three proposed inlets.

PO Box 1293

If you have any questions, you can contact me at 924-3420.

Albuquerque

New Mexico 87103

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

www.cabq.gov

C: email, Jeff@inpsectionsplus.com