F22/D22

FOURPLEXES

1 PLAN

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION

HYDROLOGY SECTION PROJ. NO. E-22 DATE: 5/9/84

PLANNING DIVISION NO. _____

CONFERENCE RECAP

SUBJECT: Lot B&C Block 1 N Holiday

ATTENDANCE:	WHO	REPRESENTING
	Ed Keiss	
	Billy Goolsby	

FINDINGS: ① Approved Grading & Drainage Plan required prior to release of building permit.
② Discharge to Public R/W allowed
③ Nuisance waters to be contained on-site with roof drains discharge to parking area.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Billy J. Goolsby
TITLE: CE/Hydrology
DATE: 5/9/84

SIGNED: [signature]
TITLE: TECH. ENCHANTMENT ENG.
DATE: 05-09-84

INFORMATION SHEET

PROJECT TITLE Fourplexes TYPE OF SUBMITTAL Drainage Plan

ZONE ATLAS PAGE NO. F-22 D22 CITY ADDRESS 5005 and 5009 Hardin Drive, NE

LEGAL DESCRIPTION Lots B and C, Block 1, Subdivision Tr. B, NEW HOLIDAY PARK, parts 5 and6

ENGINEERING FIRM Enchantment Engineering CONTACT Ed Kiess

ADDRESS Box 11571 Albq. 87192 PHONE 265-7703

OWNER Shepherd Construction. CONTACT Bob Shepherd

ADDRESS 11501 Menaul Blvd. NE PHONE 293-9595

ARCHITECT _____ CONTACT _____

ADDRESS _____ PHONE _____

SURVEYOR Enchantment Engineering CONTACT _____

ADDRESS _____ PHONE _____

CONTRACTOR Bob Shepherd CONTACT _____

ADDRESS _____ PHONE _____

DATE SUBMITTED June 11,1984

BY _____

Conference Recap attached

RECEIVED
JUN 12 1984
HYDROLOGY SECTION