HYDROLOGY

G11/D41
1 PLAN

G11/D41

1 PLAN

FLOODPLAIN CERTIFICATION
OF
3116 CORONA DRIVE N.E.



VICINITY MAP G-11
SCALE: 1" = 800'

PROJECT BENCHMARK
A SQUARE "D" CHISELED ON TOP OF CONCRETE MEDIAN CURB IN LEFT TURN BAY LOCATED ON COORS BLVD. IN MEDIAN, 165± SOUTH OF REDLANDS N.W.
ELEVATION: 5101.95 FT. (MSL 10)

LEGAL DESCRIPTION
LOT 1, BLOCK 4,
CACY ADDITION



5103.06
5099.00
Δ 4

FLOODPLAIN CERTIFICATION

AS SHOWN BY THE PLAN HEREON, THE FINISHED FLOOR ELEVATION OF THE HOUSE IS 5103.06 FEET (MSLD). PANEL 21 OF 50 OF THE NATIONAL FLOOD INSURANCE PROGRAM FLOOD BOUNDARY AND FLOODWAY MAPS FOR THE CITY OF ALBUQUERQUE SHOWS THAT THIS SITE LIES IN A DESIGNATED FLOOD HAZARD ZONE WITH AN APPROXIMATE ELEVATION OF 5099. THE ACTUAL FINISHED FLOOR ELEVATION OF 5103.06, DETERMINED FROM AN ACTUAL FIELD SURVEY, DEMONSTRATES THAT THE MINIMUM ONE-FOOT SEPARATION BETWEEN FLOOD PLAIN ELEVATION AND FINISHED FLOOR HAS BEEN SATISFIED.

Jeffrey G. Morfassis, P.E.

JEFFREY G. MORFASSIS
NEW MEXICO
8547
REGISTERED PROFESSIONAL ENGINEER
02-16

RECEIVED
FEB 17 1987
HYDROLOGY SECTION

Tom Van Metre Associates, Inc.
811 DALLAS, N.E. · ALBUQUERQUE · NEW MEXICO · 87110
ENGINEERS

JOB NO. 61731