

CITY OF ALBUQUERQUE

Planning Department
Alan Varela, Director



Mayor Timothy M. Keller

September 19, 2024

Elizabeth Willmot, PE.
Kimley Horn and Associates, Inc.
1201 3rd Ave, Suite 2800
Seattle, WA 98101

**Re: Raising Cane's Restaurant
SWC of St Joseph and Coors
Site Plan
Engineer's Stamp 9-19-24 (G11D067D)**

Dear Ms. Willmot,

The above referenced plan received 9-19-24 is approved for Building Permit by Transportation. A copy of the stamped and signed plan will be needed for each of the building permit plans. Please keep the original to be used for certification of the site for final C.O. for Transportation.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

When the site construction is completed and an inspection for Certificate of Occupancy (C.O.) is requested, use the original City stamped approved TCL for certification. Redline any minor changes and adjustments that were made in the field. A NM registered architect or engineer must stamp, sign, and date the certification TCL along with indicating that the development was built in "substantial compliance" with the TCL. Submit this certification, the TCL, and a completed Drainage and Transportation Information Sheet to the PLNDRS@cabq.gov for log in and evaluation by Transportation. **In addition, as a Condition of Certificate of Occupancy, access through Lot 8 from this site to the development internal circulation road is required, Access to be asphalt pavement a minimum of 24 feet wide.**

Once verification of certification is completed and approved, notification will be made to Building Safety to issue Final C.O. To confirm that a final C.O. has been issued, call Building Safety at 924-3690.

Sincerely,

Curtis A Cherne

Curtis Cherne, P.E.
Senior Engineer, Planning Dept.
Development Review Services

C: File