



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	The Goat Brewery				
Location:	3421 Coors Blvd NW				
Site Contact Name & Agency	Sujay Thukar - Global Storage	ESC File No.	G11E071		
	sujay.thakur@gmail.com	NPDES Id. No.	NMR10020K		
Inspection Date:	10/24/19	Start/End Time:	0930/0945		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	earthwork				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up

Weather at time of inspection?	Cloudy	Temperature: ~	48*
Estimated date of last storm 0.25" or greater	10/4/2019		

Item Number	Deficiency/ Corrective Action		
1	Track out onto Atrisco requires mitigation.		
2	Implement and install all designed BMP's for this site.		
3	Install and post NPDES posting visible to public right-of-way.		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date: none on file

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 10/24/19