

### City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

January 12, 1999

Daniel S. Aguirre, P.E. Wilson & Company 4775 Indian School Road, NE - Suite 200 Albuquerque, NM 87110

Attn: Mario Juarez-Infante

RE: GRIEGOS ELEMENTARY SCHOOL - MULTIPURPOSE BUILDING AND SITE IMPROVEMENTS (G13-D8). GRADING PLAN & DRAINAGE REPORT FOR BUILDING PERMIT APPROVAL. ENGINEER'S STAMP DATED JANUARY 11, 1999. (Prior Submittal Made November 16, 1998)

#### Dear Mr. Aguirre:

Based on the information provided on your January 11, 1999 submittal, the above mentioned project is approved for Building Permit.

After correcting Stamp date to 1999, please include a copy of this approved plan in the construction sets prior to sign-off by Hydrology.

Prior to Certificate of Occupancy approval, an Engineer's Certification per the DPM will be required.

If I can be of further assistance, please feel free to contact me at 924-3984.

Sincerely,

John P. Murray, P.E.

Hydrology

C:

Andrew Garcia

File



### City of Albuquerque

July 28, 2000

Daniel S. Aguirre, P.E. Wilson & Company 4900 Lang Avenue NE Albuquerque, NM 87109

Attn: Mario Juarez-Infante

RE: GRIEGOS ELEMENTARY SCHOOL - MULTIPURPOSE BUILDING AND SITE IMPROVEMENTS (G13-D8). ENGINEER'S CERTTIFICATION FOR CERTIFICATE OF OCCUPANCY APPROVAL. ENGINEER'S STAMP DATED JULY 26, 2000.

Dear Mr. Aguirre:

Based upon the information provided on your July 27, 2000 submittal, the above referenced project is approved for Certificate of Occupancy.

If I can be of further assistance, please feel free to contact me at 924-3984.

Sincerely,


John P. Murray, P.1

Hydrology

c·

Whitney Reierson

File



# City of Albuquerque P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

April 6, 1995

Dan Aguirre, P.E.
Wilson & Company
4775 Indian School Rd NE
Albuquerque, NM 87110

RE: GRADING & DRAINAGE PLAN FOR GRIEGOS SOCCER FIELD (G-13/D8)

RECEIVED MARCH 16, 1995 FOR GRADING PERMIT

**ENGINEER'S STAMP DATED 3-15-95** 

Dear Mr. Aguirre:

Based on the information included in the submittal referenced above, City Hydrology accepts this Grading & Drainage Plan for Grading Permit.

The Contractor must obtain a "Topsoil Disturbance Permit" from the City Environmental Health Department. The Contractor must prevent sediment from damaging adjacent properties. If any sediment washes onto adjacent property then the Contractor must remove the sediment promptly.

Engineer's Certification of grading & drainage per DPM checklist is required for this project.

If you have any questions about this project, You may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E.

Civil Engineer/Hydrology

c: Andrew Garcia

Bob Becker, APS, 915 Oak Street SE 87106



## City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

February 28, 1995

Dan Aguirre, P.E. Wilson & Company 4775 Indian School Rd NE Albuquerque, NM 87110

RE: GRADING & DRAINAGE PLAN FOR GRIEGOS SOCCER FIELD (G-13/D8), RECEIVED FEBRUARY 8, 1995 FOR BUILDING PERMIT APPROVAL ENGINEER'S STAMP DATED 2-3-95

Dear Mr. Aguirre:

Based on the information included in the submittal referenced above, City Hydrology has the following comments that must be addressed before Building Permit approval:

- 1. The legal description does not match Zone Atlas G-13. Is a plat proposed? Indicate property lines.
- 2. Conceptual Grading & Drainage Plan is required for the entire school site.
- 3. Grading & Drainage Plan for Soccer Fields must identify offsite flows and verify downstream capacity. Since the Fields appear to be in a depression where ponding has historically occurred, treat this area as if it were a floodplain and maintain the existing retention volume.

If you have any questions about this project, You may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E.

Civil Engineer/Hydrology

c: Andrew Garcia

Bob Becker, APS, 915 Oak Street SE 87106