

**From:** Patz, Logan W.  
**To:** ["Eddings, Scott"](#)  
**Subject:** 1505 Candelaria Rd. NW, Valley High school, G13D010 CO Comments  
**Date:** Friday, March 10, 2017 10:26:00 AM  
**Attachments:** [Pic Traffic.docx](#)

---

Hello Scott,

There are a few items that need to be addressed before we can release the perm CO. Pictures attached.

The ADA (handicap) sign should be updated.

There are poles around a portion of asphalt that has rutting. This should be fixed and removed.  
How will the drainage at the bus entrance be addressed.

Please Provide pictures of issues addressed and we will be able to release the CO.

Thank you.

*Logan Patz*

Planning Department  
Transportation Development  
600 2nd St. NW, Suite 201  
Albuquerque, NM 87102  
505-924-3630