

CITY OF ALBUQUERQUE



February 20, 2018

David Soule, P.E.
Inspections Plus Inc.
805 Nikanda Rd NE
Albuquerque, NM 87107

**Re: File-Gul Development
Erosion and Sediment Control Plan
Engineer's Stamp Date 2-13-18 (G13E033)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 2-15-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and is approved to be included in the Work Order construction plans with the following comment:

After the internal street is constructed, sediment BMPs may be required on the lots as the driveways are graded to drain to the internal street and the inlet protection in Matthew Ave may be able to be removed.

Include a copy of the approved plan in the Work Order construction plans.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email