## DRAINAGE INFORMATION SHEET

PROJECT TITLE:	DIRECT SER	VICES	ZONE ATLAS/DRI	NG. FILE #:	G14 1D61
DRB #:	EPC #:	<del></del>		ORDER #:	
LEGAL DESCRIPTIO			AMPBELL	ADDN	<b>No 1</b>
CITY ADDRESS: _	GECON	SD ST	NW		<u> </u>
ENGINEERING FIRM	Brasher & Loren 2201 San Pedro NE		CONTACT:	Dennis A	. Lorenz
ADDRESS:	Albuquerque, New	_		888-6088	
OWNER: ED HATTON			CONTACT:	CONTACT: SAME	
ADDRESS:	4601 4 Th	+ NW	PHONE:	343.	8008
ARCHITECT: /2	1CH BENNE	5TT	CONTACT:	5 A.N	1 E
ADDRESS:	1118 PA1214	SW	PHONE:	242.	1859
SURVEYOR:	ENGINEER	• 	CONTACT:		
ADDRESS:		, <u> </u>	PHONE:		
CONTRACTOR:	NA	;	CONTACT:	-	· · · · · · · · · · · · · · · · · · ·
ADDRESS:	·		PHONE:		
GRADING PLA  EROSION COI	EPORT  AN  GRADING & DRAINAGE  AN  OTROL PLAN  CERTIFICATION  ING:  DED  2 1 19	PLAN  PLAN  98	S. DEV. PI  X S. DEV. PI  SECTOR PLA  FINAL PLAT  FOUNDATION  BUILDING F  CERTIFICAT  GRADING PE  PAVING PER  S.A.D. DRA	T APPROVAL Y PLAT APPR AN FOR SUB AN FOR BLDG N APPROVAL Y APPROVAL Y PERMIT APP PERMIT APP	OVAL) D. APPROVAL PERMIT APPROVAL ROVAL NCY APPROVAL AL L
DATE SUBMITTED: BY:	/·2/·98 ennis A. Lorenz		*		



February 17,1998

Dennis Lorenz
Brasher & Lorenz Inc.
2201 San Pedro NE Building 1 Suite 210
Albuquerque, New Mexico 87110

RE: CONCEPTUAL DRAINAGE PLAN FOR DIRECT SERVICE (G16-D61) ENGINEER'S STAMP DATED 1/21/98

Dear Mr. Lorenz:

Based on the information provided on your January 21,1998 submittal, the above referenced site is approved for Site Development Plan For Building Permit.

Please be advised that the following concerns must be addressed prior to Building Permit release:

- 1. Top of curb elevations on both streets.
- 2. Swale slopes on the plan drawings.

If I can be of further assistance, please feel free to contact me 924-3986.

C: Andrew Garcia

Sincerely -

Serne Montoya CE
Associate Engineer