

CITY OF ALBUQUERQUE



September 18, 2012

Joseph J. Casares Jr., P.E.
Insight Construction
P.O. Box 6653
Albuquerque, NM 87102

Re: 3909 12th St. Office Improvements
Grading and Drainage Plan
Engineer's Stamp date 9-11-12 (G14/D083)

Dear Mr. Casares,

Based upon the information provided in your submittal received 9-13-12, the above referenced plan cannot be approved for Grading Permit and Building Permit until the following comments are addressed.

- A topographic map needs to be provided.
- Water blocks are needed at entrances/exits.
- Depress all landscape areas.
- Spot elevations are needed for the properties to the west.

If you have any questions, you can contact me at 924-3695 or Rudy Rael at 924-3977.

Sincerely,

Shahab Biazar, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: RER/SB
e-mail

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov